

ATW

CLOSED CIRCUIT COOLER



ADVANCED **T**ECHNOLOGY IN
INDUCED DRAFT, COUNTERFLOW COOLERS

EASY SOLUTIONS... BETTER CHOICES!

CERTIFIED EN ISO 9001



ATW



Since its founding in 1976, EVAPCO, Inc. has become a world-wide leader in supplying quality cooling equipment for thousands of customers in both the commercial and industrial markets.

EVAPCO's success has been the result of a continual commitment to product improvement, quality workmanship and a dedication to providing unparalleled service.



Our emphasis on research and development has led to many product innovations – a hallmark of EVAPCO through the years.

The ongoing R & D Program enables EVAPCO to provide the most advanced products in the industry – technology for the future, available today.

EVAPCO products are manufactured on five continents around the world and distributed through hundreds of factory authorized sales representatives.

DESIGN AND CONSTRUCTION FEATURES

The ATW line of evaporative coolers reflects EVAPCO's commitment to product development. Their advanced design provides owners with many operational and performance advantages.

These induced draft, counterflow coolers are designed for easy maintenance and long, trouble-free operation.

Easy to Service Motor Mount Design

- All normal maintenance can be performed quickly from outside the unit
- Designed for easy belt adjustment
- Extended lube lines for easy bearing lubrication
- If required, motor may swing to outside for easy removal



Water Saver Drift Eliminators

- New patented design reduces drift rate to < 0.001%
- Saves water and reduces water treatment cost
- Greater structural integrity vs. old style blade-type
- Recessed into casing for greater protection
- Drift rate certifications with Eurovent OM-14-2009



PVC Spray Distribution Header with ZM II™ Nozzles

- Large orifice nozzles prevent clogging (no moving parts)
- Nozzles are threaded into header at proper orientation
- Fixed position nozzles require zero maintenance
- Guaranteed for life



Totally Enclosed Pump Motors

- Help assure long, trouble-free operation

Stainless Steel Strainers

- Resists corrosion better than other materials



Z-725 Heavy Mill Hot-Dip Galvanized Steel Construction

(Stainless steel available as affordable option)



Advanced Design Smooth Flow Fans

- Totally Enclosed Fan Motors assures long life
- Power-Band Belts for Better Lateral Rigidity
- Advanced Design Aluminum Fan Blades
- Non-corroding Cast Aluminum Sheaves
- Heavy-Duty Fan Shaft Bearings with L-10 life of 75,000 - 135,000 hrs
- All Other Components Corrosion Resistant Materials

Low Sound Options available
Refer to page 11



Super Low Sound Fan (optional)

- Extremely wide sloped fan blades for sound sensitive applications
- One piece molded heavy duty construction
- 9-15 dB(A) sound reduction

Patented Thermal-Pak® Coil Design
Features EVAPCO's exclusive CROSSCOOL™

Features EVAPCO's exclusive **CROSSCOOL™** tube enhancement for greater internal heat transfer. All EVAPCO Closed Circuit Coolers utilize EVAPCO's patented Thermal-Pak® coil design which assures greater operating efficiency. The elliptical tube design allows for closer tube spacing, resulting in greater surface area per plan area than round-tube coil designs. In addition, the Thermal-Pak® design has lower resistance to airflow and also permits greater water loading, making the Thermal-Pak® coil the most effective design available.



Thermal-Pak® Coil



Thermal-Pak® Coil by EVAPCO



Round Tube Coil by Others

IBC Compliant Design
Refer to page 17



"Clean Pan" Basin Design

- Access from all four sides
- Large open area simplifies maintenance
- Basin may be inspected with pumps running
- Sloped basin design prevents sediment buildup, biological film and standing water

WST Air Inlet Louvers (Water and Sight Tight)

- Easily removable for access
- Patented design keeps sunlight out—preventing biological growth
- Keeps water in while keeping dirt and debris out
U.S. Patent No. 7927196

Louver Access Door

- Hinged access panel with quick release mechanism
- Allows easy access to perform routine maintenance and inspection of the make-up assembly, strainer screen and basin
- Available on larger models



Easy Field Assembly

- A new field assembly seam design which ensures easier assembly and reduced potential for field seam leaks
- Self-guided channels guide the fan casing section into position improving the quality of the field seam
- Eliminates up to 66% of fasteners



SPECIFICATIONS

ENGINEERING

IBC

SOUND

APPLICATIONS

OPTIONS

DESIGN

ATW

DESIGN FEATURES

EVAPCOAT Corrosion Protection System

EVAPCO, long known for using premium materials of construction, has developed the ultimate system for corrosion protection in galvanized steel construction – the EVAPCOAT Corrosion Protection System. Marrying corrosion free materials with heavy gauge mill hot-dip galvanized steel construction to provide the longest life product with the best value.

The Evapcoat Corrosion Protection System consist of:


- **Z-725 Mill Hot-Dip Galvanized Steel Construction**

Mill hot-dip galvanized steel has been successfully used for over 25 years for the protection of evaporative coolers against corrosion. There are various grades of mill galvanized steel each with differing amounts of zinc protection. EVAPCO has been a leader in the industry in developing heavier galvanizing, and was the first to standardize on Z-600 mill hot-dip galvanized steel. Now, EVAPCO is, once again, increasing the level of corrosion protection by being the first and only manufacturer in Europe to use Z-725 mill hot-dip galvanized steel.

Z-725 designation means there is a minimum of 725 g of zinc per m² of surface area present on the steel.

Z-725 is the heaviest level of galvanizing available for manufacturing evaporative coolers and has over 2.5 times more zinc protection than competitive designs using Z-275 steel. With Z-725 mill hot-dip galvanized steel construction, EVAPCO provides galvanized steel panels with corrosion protection that approaches the level of the hot-dip galvanized heat exchanger coils.

During fabrication, all panel edges are coated with a 95% pure zinc-rich compound for extended corrosion resistance.



- **Type 304 Stainless Steel Strainers**

Subjected to excessive wear and corrosion, the sump strainer is critical to the successful operation of the cooler. EVAPCO uses only stainless steel for this very important component.

- **PVC Air Inlet Louvers**

The innovative design uses corrosion free materials while effectively eliminating splash out and reducing the potential for algae formation inside the cooler.

- **PVC Drift Eliminators**

The final elements in the upper part of the cooler are moisture eliminators which strip the entrained water droplets from the leaving air stream.

EVAPCO eliminators are constructed entirely of inert, corrosion-free PVC. This PVC material has been specially treated to resist damaging ultraviolet light. The eliminators are assembled in easily handled sections to facilitate removal thereby exposing the upper portion of the unit and water distribution system for periodic inspection.

- **PVC Water Distribution System, ZM II™ Spray Nozzle**

The fixed position ZM II™ Spray Nozzles are mounted in corrosion-free PVC water distribution pipes. Together, these elements combine to provide unequaled coil coverage, scale prevention and make the industries best performing non-corrosive, maintenance-free water distribution system.

- **Totally Enclosed Motors**

EVAPCO uses totally enclosed motors for all fan and pump motors as standard. These superior motors help to assure longer equipment life without motor failures, which result in costly downtime.

- **Alternate Materials of Construction**

EVAPCO induced draft coolers have a modular design which allows for specific areas to be enhanced for increased corrosion protection. For particularly corrosive environments, EVAPCO coolers are available with Stainless Steel construction for the basin, casing and/or coil.

- **Stainless Steel Welded Basin**

The basin area of a cooler is often subjected to high concentrations of impurities and silt. In addition to the EVAPCOAT Corrosion Protection System, EVAPCO offers optional stainless steel construction for superior corrosion resistance. This option provides Type 304 or Type 316 stainless steel for the entire basin section - including the support columns and air inlet louver frames.

- **Stainless Steel Coils**

The heat exchanger coil is the heart of the evaporative cooler. For this critical component, EVAPCO offers the options of Type 304 or type 316 stainless steel construction.

NOTE: Closed Circuit Coolers should only be used on sealed, pressurized systems. Continual aeration of the water in an open system can cause corrosion inside the tubes of the cooler leading to premature failure.

DESIGN FEATURES

ATW

Axial Fan Drive System Direct Drive Units – 1.2 m Wide Models

ATW 9 to ATW 48

The T.E.F.C. motors are located on the outside of the unit on Models ATW 9-2C-2 through ATW 48-5G and are protected by a hinged, swing away cover.



External Motor Mount (with swing away cover)

Belt Drive Units – 2.4 m and 2,3 m Wide Models

ATW 64 to ATW 332

The fan motor and drive assembly on these units are designed to allow easy servicing of the motor and adjustment of the belt tension from the exterior of the unit. The T.E.F.C. fan motor is mounted on the outside of these models.



External Motor Mount (with optional ladder)

A large hinged access door with a “quick release” latch provide access to the fan section for maintenance.

NOTE: the sloped access ladder is available on all ATW 64 through ATW 866. Please check conformity with local legislation before application.

Belt Drive Units – 3 m & 3.6 m Wide Models

ATW 120 to ATW 362 - ATW 144 to ATW 866

Designed as the ideal replacement cooler, these models provide both cost effective and energy efficient alternatives to obsolete centrifugal fan designs. The 3 m wide plan areas are also well suited for new installations and provide more layout flexibility. The unique belt drive design features are detailed below.



Motor Base Assembly

The fan motor and drive assembly is designed to allow easy servicing of the motor and adjustment of the belt tension from the exterior of the unit. The T.E.A.O. fan motor is located inside the fan casing on a rugged heavy duty motor base. The innovative motor base also features a unique locking mechanism for a positive adjustment.

The motor base is designed to swing out through a very large 1.3 m² access opening. This allows for easy servicing of the motor.



Motor Access

Power- Band Drive Belt: The Power-Band is a solid-back, multigroove belt system that has high lateral rigidity. The belt is constructed of neoprene with polyester cords. The drive belt is designed for 150 percent of the motor nameplate kW for long life and durability.

Fan Shaft Bearings: The fan shaft bearings in ATW units are specially selected for long, trouble-free life. They are rated for an L-10 life of 75,000 to 135,000 hours and are the heaviest pillow block bearings available.

Aluminum Alloy Pulleys: Fan pulleys are constructed of corrosion free aluminum for long life. The aluminum also helps belts last longer.

ATW

DESIGN FEATURES

Water Management High Efficient Water Saver Drift Eliminators


An extremely efficient drift eliminator system is standard on EVAPCO coolers. The patented system removes entrained water droplets from the air stream to limit the drift rate to less than 0.001% of the recirculating water rate. With a low drift rate, EVAPCO coolers save valuable water and water treatment chemicals. The drift eliminators are constructed of an inert polyvinyl chloride (PVC) plastic material which effectively eliminates corrosion of these vital components. They are assembled in sections to facilitate easy removal for inspection of the water distribution system.



Superior WST Air Inlet Louver and Screen Design

EVAPCO's patented WST Inlet Louvers keep water in and sunlight out of the basins of induced draft products. The unique non-planar design is made from light-weight PVC sections which easily fit together and have no loose hardware, enabling easy basin access.

Developed with computational fluid dynamics (CFD) software, the louver's air channels are optimized to maintain fluid dynamic and thermodynamic efficiency and block all line-of-sight paths into the basin eliminating splash-out; even when the fans are off. Additionally, algae growth is minimized by blocking all sunlight.




Inlet Louver Material

The combination of easy basin access, no splash-out and minimized algae growth saves the end user money on maintenance hours, water consumption and water treatment costs.

"Clean Pan" Basin Design

EVAPCO coolers features a completely sloped basin from the upper to lower pan section. This "Clean Pan" design allows the water to be completely drained from the basin. The cooler water will drain from the upper section to the depressed lower basin section where the dirt and debris can be easily flushed out through the drain. This design helps prevent buildup of sedimentary deposits, biological films and minimizes standing water.



Sloped Basin

ZM II™ Spray Nozzle Water Distribution System

Even and constant water distribution is paramount for reliable, scale-free evaporative cooling. EVAPCO's Zero Maintenance ZM II™ Spray Nozzle, mounted in a PVC distribution pipe, remains clog-free under the toughest conditions to deliver approximately 4 l/s to every square meter of coil plan area.

The heavy-duty nylon ZM II™ Spray nozzles have a 33 mm diameter opening and a 38 mm splash plate clearance, enabling EVAPCO to use 75% fewer nozzles.



ZM II™ Nozzle

OPTIONAL EQUIPMENT

ATW

Two Speed Motors

Two speed fan motors can provide an excellent means of capacity control. In periods of lightened loads or reduced wet bulb temperatures, the fans can operate at low speed, which will provide about 60% of full speed capacity, yet consume only about 15% of the power compared with high speed. In addition to the energy savings, the sound levels of the units will be greatly reduced at low speed.


Inverter Duty Motors

Inverter Duty motors are available for cooler applications which utilize variable frequency drive systems for capacity control. Inverter Duty motors offer totally enclosed premium efficiency construction which is designed for variable frequency drive applications.

Note: Other special motor configurations are available to meet specific proper requirements. Contact your local EVAPCO sales representative for application assistance and motor availability.


Remote Sump Configuration

For units operating in areas where temperatures may be very low, or where low temperatures may occur during periods when the unit is not operating, a sump located inside the building is the preferred means of ensuring that the basin water will not freeze. For these applications, the cooler will be supplied without the spray pump, suction strainers and all associated piping, but with an oversize bottom outlet.




Basin Heater Package

If a remote sump configuration is not practical, electric basin heater packages are available to help prevent freeze-up of the basin water. The packages include electric heater elements and a combination with thermostat and low water cut-off. (Consult EVAPCO for heater size and application)



Electric Water Level Control

Evaporative coolers may be ordered with an electric water level control in lieu of the standard mechanical float and make-up assembly. This package provides accurate control of water levels and does not require field adjustment.



Multiple Circuit Coils

Coolers may be supplied with multiple circuit coils to match various system requirements such as split systems.

Self Supporting Service Platforms

Coolers are available with self-supporting service platforms that include access ladders which are designed for easy field installation. This option offers significant savings in comparison to field constructed, externally supported catwalks. The EVAPCO service platform option will be installed in front of the fan access doors.

Motor Davit

In the event that a fan and/or fan motor should need to be replaced, a motor davit is available from which a chain fall can be mounted to easily lower the motor/fan to the ground.



ATW Cooler with Optional Service Platform and Motor Davit

ATW

APPLICATION

Design

Evapco units are of heavy-duty construction and designed for long trouble-free operation. Proper equipment selection, installation and maintenance is, however, necessary to ensure full unit performance. Some of the major considerations in the application of a cooler are presented below. For additional information, please contact the factory.

Air Circulation

It is important that proper air circulation be provided. The best location is on an unobstructed roof top or on ground level away from walls and other barriers. Those closed circuit coolers located in wells, enclosures or adjacent to high walls must be properly located to avoid the problems associated with recirculation.

Recirculation raises the wet bulb temperature of the entering air causing the water temperature to rise above the design. For these cases, the discharge of the fan should be located at a height even with the adjacent wall, thereby reducing the chance of recirculation. For additional information, see the Evapco Equipment Layout Manual.

Good engineering practice dictates that the closed circuit cooler discharge air not be directed or located close to or in the vicinity of building air intakes.

Piping

Cooler piping should be designed and installed in accordance with generally accepted engineering practices. The piping layout should be symmetrical on multiple unit systems, and sized for a reasonably low water velocity and pressure drop. The standard closed circuit cooler is recommended only on a closed, pressurized system. The piping system should include an expansion tank to allow for fluid expansion and purging air from the system.

Note: Closed Circuit Coolers should never be used on an open system. Continual aeration of the water in an open system can cause corrosion inside the tubes of the cooler leading to premature failure.

The piping system should be designed to permit complete drainage of the heat exchanger coil. This will require a vacuum breaker or air vent to be installed at the high point and a drain valve installed at the low point of the piping system. Both must be adequately sized.

All piping should be securely anchored by properly designed hangers and supports. No external loads should be placed upon the cooler connections, nor should any of the pipe supports be anchored to the cooler framework.

Recirculating Water System

The surest way to protect the recirculating water system from freezing is with a remote sump. The remote sump should be located inside the building and below the unit. When a remote sump arrangement is selected, the spray pump is provided by others and installed at the remote sump. All water in the closed circuit cooler basin should drain to the remote sump when the spray pump cycles off. Refer to page 7 for concept illustration.

Other freeze protection methods are available when a remote sump is not feasible. Electric pan heaters, steam or hot water coils can be used to keep the pan water from freezing when the unit cycles off. Water lines to and from the unit, spray pump and related piping should be heat traced and insulated up to the overflow level in order to protect from freezing.

The unit should not be operated dry (fans on, pump off) unless the basin is completely drained and the unit has been designed for dry operation. Consult the factory when dry operation is a requirement.

Freeze Protection

If the units are installed in a cold climate and operated year-round, freeze protection must be provided for the heat exchanger coil in the unit as well as for the recirculating water system.

Minimum Flows		
MODELS		l/s
ATW	9, 16	1,64*
ATW	24, 36, 48	2,34*
ATW	64, 72, 84, 96, 112, 142, 166	10,1
ATW	120, 180	11,9
ATW	241, 360	23,8
ATW	192, 224, 284, 332,	20,2
ATW	166W, 192W, 224W	
ATW	144, 168, 216	14,7
ATW	242, 362	23,8
ATW	286, 334, 430	29,3
ATW	290, 338, 434	
ATW	578, 672, 866	58,6

* serial flow

Heat Exchanger Coil

The simplest and most foolproof method of protecting the heat exchanger coil from freeze-up is to use a glycol solution. If this is not possible, an auxiliary heat load must be maintained on the coil at all times so that the water temperature does not drop below 10°C when the cooler is shut down. Also, a minimum recommended flow rate must be maintained. Refer to Heat Loss Data Table on page 35 for heat loss data.

Water Treatment

In some cases the make-up water will be so high in mineral content that a normal bleed-off will not prevent scaling. In this case, water treatment will be required and a reputable water treatment company familiar with the local water conditions should be consulted.

Units constructed of galvanized steel operating with circulating water having a pH of 8,3 or higher will require periodic passivation of the galvanized steel to prevent the formation of "white rust".

Any chemical water treatment used must be compatible with the galvanized construction of the unit. If acid is used for treatment, it should be accurately metered and the concentration properly controlled. The pH of the water should be maintained between 7 and 8,8. Batch chemical feeding is not recommended because it does not afford the proper degree of control. If acid cleaning is required, extreme caution must be exercised and only inhibited acids recommended for use with galvanized construction should be used.

Control of Biological Contamination

Water quality should be checked regularly for biological contamination. If biological contamination is detected, a more aggressive water treatment and mechanical cleaning program is required. The water treatment program should be performed in accordance with local legislation and in conjunction with a qualified water treatment company.

It is important that all internal surfaces be kept clean of accumulated dirt or sludge. In addition, the drift eliminators should be kept in good operating condition to minimize water from exiting the evaporative cooling unit in the discharge air. To minimize the risk of biological contamination, at initial start up or after an extended shut down, it is recommended that the cooler be properly treated. Clean all debris such as leaves and dirt from the unit. Completely fill the basin to the overflow level with fresh water. Initiate a biocide water treatment or shock treatment program prior to operating the unit. It is preferable that all such procedures be conducted or supervised by a water treatment specialist.

APPLICATION



FM Approval



FM (Factory Mutual) Global is a mutual insurance company, which evaluates hazards and recommends improvements to property to reduce risks if a disaster like fire occurs.

EVAPCO's ATW closed circuit cooler can be executed to meet the FM approval standard.

To be in compliance with this standard the closed circuit coolers are improved with the following modifications:

- Water distribution system constructed of galvanized or stainless steel instead of PVC. Nozzles remain ABS plastic.
- Special full scale tested and approved PVC louver and eliminator material.
- Internal partition walls between cells and louver screens to avoid fire propagation.
- Air inlet louvers are provided with 1" x 1" hot dipped galvanized or stainless steel screens in front of the PVC air inlet material.
- Units with louvers more than 4' tall are provided with galvanized or stainless steel fire-walls which extend out from the unit 12" and are attached to the vertical supports between adjoining cells.
- Increased thickness of steel construction panels to improve fire resistance.
- Aluminum axial fans on single cell units, SLSF only on multi cell units for redundancy.

Technical Support Services

EVAPCO's evapSelect™ Equipment Selection Program

EvapSelect™ is a Web based computer selection program which allows the design engineer to choose EVAPCO models and optimize unit selections. The program allows the engineer to evaluate the equipment's thermal performance, space, energy requirements and water consumption. Once the model is selected and optional equipment features are inserted, the engineer may output a complete specification **AND** a unit drawing from this program.

The software is designed to provide the user with maximum flexibility in analyzing the various selection parameters while in a friendly and familiar Windows format.

The EvapSelect™ software is available to all consulting engineering offices and design-build contractors. The programs are distributed through the local EVAPCO sales representative or the EVAPCO offices.

EVAPCO's Website

Log on to EVAPCO's new and improved website <http://www.evapco.eu> for expanded product information. Product literature, Rigging and Maintenance Instructions are all accessible online from your computer. The EvapSelect™ Equipment Selection Software program may be accessed using Microsoft Internet Explorer after contacting your local EVAPCO sales representative. Users may make Requests for Quotation through the website or by e-mailing EVAPCO at this address:

evapco.europe@evapco.eu

With the EvapSelect™ program, equipment selections, written specifications, unit drawing files and EVAPCO on-line information are readily available from the comfort of your own office!



APPLICATIONS

ATW

APPLICATION

Principle of Operation

The process fluid is circulated through the coil of the closed circuit cooler. Heat from the process fluid is dissipated through the coil tubes to the water cascading downward over the tubes. Simultaneously, air is drawn in through the air inlet louvers at the base of the cooler and travels upward over the coil opposite the water flow. A small portion of the water is evaporated which removes the heat. The warm moist air is drawn to the top of the closed circuit cooler by the fan and is discharged to the atmosphere. The remaining water falls to the sump at the bottom of the cooler where it is recirculated by the pump up through the water distribution system and back down over the coils.



Air Conditioning

- Unitary Heat Pump Systems
- Computer Room Cooling
- Refrigeration Supplement

Manufacturing

- Air Compressors
- Plastic Mold Machines
- Transformers
- Engines

Steel Mills & Foundries

- Quench Tanks
- Rolling Mills
- Induction Furnaces
- Continuous Casters

Industrial Fluids

- Hydraulic Oils
- Plating Solutions
- Quench Oils

APPLICATIONS


ATW



Ultra Quiet Closed Circuit Coolers

The ATW Closed Circuit Cooler is now available with four (4) equipment options to reduce the overall sound generated from the side or top of the ATW Closed Circuit Cooler.

Each option provides various levels of sound reduction and can be used in combination to provide the lowest sound level.



**Ultra Quiet operation
for induced draft
counterflow
Closed Circuit Coolers**

SOUND

ATW

ADVANCED TECHNOLOGY LOW SOUND SOLUTIONS

Super Low Sound Solution for Sound Sensitive Applications



Family of Super Low Sound Fans

The Super Low Sound Fan

Reduced Sound Levels versus Model ATW Standard Fan


EVAPCO's Super Low Sound Fan on the ATW Closed Circuit Coolers utilizes an extremely wide chord blade design applied for sound sensitive applications where the lowest sound levels are desired. The fan is one piece molded heavy duty FRP construction utilizing a forward swept blade design. The Super Low Sound Fan reduces sound levels 9 to 15 dB(A) compared to the Model ATW standard fan.

Improved Sound Quality versus Model ATW Standard Fan

The SUPER Low Sound Fan on the ATW Closed Circuit Cooler reduces sound levels 9-15 dB(A) and eliminates audible blade passing frequencies indicative of straight bladed axial type fans.

Refer to the Narrow Band Spectrum graph which shows how straight bladed axial fans produce blade passing frequencies – the same phenomena that produce the signature pulsating helicopter noise.

The blade passing frequencies are audible spikes in sound pressure levels, but are not apparent in the octave band sound spectrum.



The Super Low Sound Fan on the ATW Closed Circuit Cooler reduces sound levels and betters the sound quality!

NOTE: These low sound options may impact the overall installed dimensions of the ATW Closed Circuit Cooler selected.

SOUND

ADVANCED TECHNOLOGY LOW SOUND SOLUTIONS

ATW


Additional Solutions for Sound Sensitive Applications



Low Sound Fan 4 – 7 dB(A) Reduction!

The Low Sound Fan offered by EVAPCO is a wide chord blade design for sound sensitive applications where low sound levels are desired. The Low Sound Fan shall utilize a unique soft-connect blade-to-hub design that is compatible with Variable Speed Drives.

The Low Sound Fan is capable of reducing the unit sound pressure levels 4 dB(A) to 7 dB(A), depending upon specific unit selection and measurement location. The fans are high efficiency axial propeller type and are available on 2.4 m wide and larger ATW Closed Circuit Coolers.



Water Silencer

Reduces Water Noise in the Cold Water Basin up to 7 dB(A)!

The water silencer option is available for all induced draft models and is located in the falling water area of the cold water basin. The water silencer will reduce the high frequency noise associated with the falling water and is capable of reducing overall sound levels **4 dB(A) to 7 dB(A)** measured at 1.5 m from the side or end of the unit. The water silencers reduce overall sound levels **9 dB(A) to 12 dB(A)** (depending on water loading and louver height) measured 1.5 m from the side or end of the unit when water is circulated with fans off.

The water silencers are constructed of lightweight PVC sections and can be easily removed for access to the basin area. *The water silencer will have no impact on unit thermal performance.*

The Water Silencer is available on ALL ATW Closed Circuit Coolers.

Consult EVAPCO's **EvapSelect™** selection software for unit sound levels. If a detailed analysis or full octave band data sheet is required for your application, please consult your EVAPCO Sales Representative.

Background in Sound Basics

Sound


Sound is the alteration in pressure, stress, particle displacement and particle velocity, which is propagated in an elastic material. Audible sound is the sensation produced at the ear by very small pressure fluctuations in the air.

Sound Pressure

Sound pressure is the *intensity* of sound. Sound pressure, L_p in decibels is the ratio of measured pressure, P in the air to a reference sound pressure, $P_0 = 2 \times 10^{-5}$ Pascal following the following formula:

$$L_p \text{ (dB)} = 10 \log_{10} (\Delta P^2 / \Delta P_0^2)$$

The most important point to understand about sound pressure level is that **sound pressure level is what is actually being measured when sound data is recorded.** Microphones that measure sound are pressure sensitive devices that are calibrated to convert the sound pressure waves into decibels.



"SOUND PRESSURE"


Similar to the intensity coming from a light bulb which gets dimmer as one gets further and further away, sound pressure decreases in decibels as your ear gets further from the sound source.

Sound Power

Sound Power is the *energy* of sound. Sound power, L_w in decibels is the ratio of the calculated sound power, W to a reference power, $W_0 = 1$ picowatt, according to the following formula:

$$L_w \text{ (dB)} = 10 \log_{10} (W/W_0)$$

The most important point to remember about **sound power level is that sound power level is not a measured value, but is calculated based on the measured sound pressure.**




"SOUND POWER"

Similar to the wattage of a light bulb that does not change the farther one is away from the light bulb, sound power does not vary with distance.

Adding Multiple Sound Sources

Since the decibel is a logarithmic function, the numbers are not added linearly. Therefore, two 73 dB sound sources added together do not equal 146 dB. The resultant sound would actually be 76 dB. The following table shows how to add decibels from two sound sources.

Difference in dB Level	Add to the higher dB Level
0 to 1	3
2 to 3	2
4 to 8	1
9 or greater	0




SOUND BASIC



Sound Science and Closed Circuit Coolers

Sound Frequency



Fan Noise

- Low / Mid frequencies that travel long distances, through walls, and around obstructions.
- Very difficult to attenuate. Reduce fan noise by using Low Sound Fans.
- Dominates what is measured and heard at the Closed Circuit Cooler and at the sound sensitive location.

Water Noise

- High frequencies that attenuate naturally with distance. Attenuated easily by walls, trees or other obstructions.
- Totally masked and drowned out by fan noise at a short distance away from the Closed Circuit Cooler.

Sound Pressure – The A-Weighted Scale

The A-weighted scale, dB(A) is a means to translate what a sound meter microphone measures to how the human ear perceives the sound.

dB(A) Formula and Conversions:

$$dB(A) = 10 \log_{10} \sum_{f=63}^{f=8000} 10^{((dB+C_f)/10)}$$

where: C_f = correction factor per band
 dB = measured sound pressure
 let: $Z_f = (dB + C_f)/10$

Band	Center Freq. (Hz)	Frequency Range (Hz)	Sample Data (dB)	C _f (dB)	Z _f
1	63	44-88	68	-26.2	4.18
2	125	89-175	76	-16.1	5.99
3	250	176-350	77	-8.6	6.84
4	500	351-700	73	-3.2	6.98
5	1000	701-1400	70	0	7.00
6	2000	1401-2800	68	+1.2	6.92
7	4000	2801-5600	71	+1.0	7.20
8	8000	5601-11200	73	-1.1	7.19

Typical Sound Pressure Levels of Well Known Noises:

Jet Airplane, 45 meters away	140 dB(A)
Painful	130 dB(A)
Very Uncomfortable	120 dB(A)
Circular Saw	110 dB(A)
Nightclub	100 dB(A)
Semi Truck	90 dB(A)
Sidewalk of a Busy Road	80 dB(A)
Household Vacuum, 1 meter away	70 dB(A)
Normal Conversation	60 dB(A)
Inside Average Home	50 dB(A)
Quiet Library	40 dB(A)
Bedroom at Night	30 dB(A)

Notable Facts about Sound:

- +/- 1 dB(A) is inaudible to the human ear
- Decreasing a noise source by 10 dB(A) sounds half as loud to the human ear

Example calculation of the dB(A) formula using the Sample Data above.

$$dB(A) = 10 \log_{10} \sum 10^{Z_1} + 10^{Z_2} + 10^{Z_3} + 10^{Z_4} + 10^{Z_5} + 10^{Z_6} + 10^{Z_7} + 10^{Z_8}$$

$$= 10 \log_{10} (67114245.2) = 78.3 \text{ dB(A)}$$

Sound Verifications

Specify sound pressure in dB(A) measured 1,5 m above the fan discharge during full speed operation.


- All manufacturers can meet a performance specification with Low Sound Options
- Fan noise is what matters. 1,5 m above the fan is where it matters.

Measurement Location

Per Cooling Technology Institute Standard ATC-128


Sound Microphone location 1,5 m above the closed circuit cooler fan cowl edge at a 45° angle.

This position assures accurate sound measurements by eliminating a source of uncertainty by taking the microphone out of the high velocity fan discharge air.



Easy Verification

At 1,5 m from the Closed Circuit Cooler, a sound meter records only closed circuit cooler noise. Interested parties can easily verify the actual noise coming from the closed circuit cooler against the specified sound data with good certainty.



If sound were specified at 15 meters or some greater distance from the sound sensitive location, there is increased uncertainty in the measured data due to other possible sound sources within the 15 meters radius of the sound microphone.

Sound Quality

Sound coming from the top of the closed circuit cooler is comprised of low- and mid-frequency fan noise. Low- and mid-frequency fan "rumble" is very difficult to attenuate. Fan rumble travels through everything and around everything and what is audible at any sound sensitive location.


Sound coming from the sides of the Closed Circuit Cooler is comprised of high frequency water noise, is much less objectionable than fan noise and attenuates naturally with distance.

Acoustical Shadow*

"Subjective reactions to the overall noise generated by Closed Circuit Coolers indicate that as one walks away from a tower intake, a point is reached where the water noise is masked by the fan noise. The point coincides with the point at which one emerges from the acoustical shadow of the Closed Circuit Cooler structure, which shields intake water noise from discharge fan noise."

*Seelbach & Oran, "What To Do About Cooling Tower Noise", Industrial Acoustics Company.

Sound measured at the side of a Closed Circuit Cooler is inside the acoustical shadow of the noise emitted from the top. Outside the acoustical shadow, the low- and mid-frequency fan noise completely masks the high frequency water noise.



Specify fan noise because it matters! Specify fan noise where it matters!

ATW



The International Building Code (IBC) is a comprehensive set of regulations addressing the structural design and installation requirements for building systems – including HVAC and industrial refrigeration equipment.

With the advent of the IBC, EVAPCO is proud to introduce the new and improved line of ATW Closed Circuit Coolers with IBC 2012 compliance standard.



We Stand Tall Through it All!

Wind, Rain, Earthquake and Hurricane

EVAPCO Closed Circuit Coolers... designed to withstand seismic or wind load forces.

ATW

IBC COMPLIANCE

In its continuing commitment to be the leaders in evaporative cooling equipment design and services, EVAPCO ATW Closed Circuit Coolers are now **Independently Certified** to withstand Seismic and Wind Loads in accordance with IBC 2012.

What is IBC?

International Building Code

The International Building Code (IBC) is a comprehensive set of regulations addressing both the structural design and the installation requirements for building systems – including HVAC and industrial refrigeration equipment. Compared to previous building codes that considered only the building structure and component anchorage, the requirements contained within the IBC address anchorage, structural integrity, and the operational capability of a component following either a seismic or wind load event. **Simply stated, the IBC code provisions require that evaporative cooling equipment, and all other components permanently installed on a structure, must be designed to meet the same seismic or wind load forces as the building to which they are attached.**

How Does IBC 2012 Apply to Closed Circuit Coolers?

Based on site design factors, calculations are made to determine the equivalent seismic “g force” and wind load (kilo-Newton per square meter, kN/m²) on the unit. The closed circuit cooler must be designed to withstand the greater of either the seismic or wind load.

The New ATW is offered with a choice of TWO structural design packages:

- **Standard Structural Design** – For projects with ≤1.0g seismic or 6,94 kN/m² wind loads
- **Upgraded Structural Design** – Required for projects with >1.0 g seismic or 6,94 kN/m² wind loads

All locations with design criteria resulting in a seismic design force of up to 1.0g or a wind load of 6,94 kN/m² or below will be provided with the standard ATW structural design. An upgraded structural design is available for installations with design criteria resulting in “g forces” greater than 1.0g. The highest “g force” location in North America is 5.12g. The highest wind load shown on the maps is 273 km/h, which is approximately equal to 6,94 kN/m² velocity pressure. **Therefore, the upgraded structural design package option for the New ATW is designed for 5.12 g and 6,94 kN/m² making it applicable to most building locations worldwide.**

Design Implementation


EVAPCO applies the seismic design and wind load information provided for the project to determine the equipment design necessary to meet IBC requirements. This process ensures that the mechanical equipment and its components are compliant per the provisions of the IBC as given in the plans and specifications for the project.

Independent Certification


Although the IBC references and is based on the structural building code ASCE 7, many chapters and paragraphs of ASCE 7 are superceded by the IBC, independent certification and methods of analysis are such paragraphs. Per the most recent edition of the code, the EVAPCO compliance process included an exhaustive analysis by an independent approval agency. As required by the International Building Code, EVAPCO supplies a certificate of compliance as part of its submittal documents. The certificate of compliance demonstrates that the equipment has been independently tested and analyzed in accordance with the IBC seismic and wind load requirements. Evapco has worked closely with the independent approval agency, The VMC Group, to complete the independent equipment testing and analysis.

If the seismic “g force” or wind load psf requirements for the project site are known, EVAPCO’s online equipment selection software **EvapSelect™**, will allow you to choose the required structural design package – either standard construction or upgraded construction.

For further questions regarding IBC compliance, please contact your local EVAPCO Representative.





ATW



Engineering Data & Dimensions

MODELS: 9-2C-2 TO 16-5F-2



Note: The number of coil connections doubles when the flow rate exceeds 28 l/s on Models ATW 9-2C-2 thru ATW 16-5F-2.

ATW Model* No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)					
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd**	Conn. Size(mm)	Operating Weight	H	U	E	A	L	W
9-2C-2	522	395	762	0,75	2,17	0,55	61	170	150	654	2429	1632	797	305	908	927
9-3C-2	595	468	858	0,75	2,11	0,55	79	170	150	749	2645	1848	797	521	908	927
9-4C-2	658	531	939	0,75	2,05	0,55	98	170	150	830	2861	2064	797	737	908	927
9-4D2	663	536	945	1,1	2,32	0,55	98	170	150	835	2861	2064	797	737	908	927
9-5C-2	726	599	1026	0,75	1,99	0,55	117	170	150	917	3077	2280	797	953	908	927
9-5D-2	731	604	1030	1,1	2,25	0,55	117	170	150	921	3077	2280	797	953	908	927
16-2E-2	776	599	1207	1,5	4,08	0,55	98	305	150	1048	2584	1628	956	305	1213	1231
16-3E-2	908	731	1375	1,5	3,96	0,55	136	305	150	1216	2775	1819	956	495	1213	1231
16-4E-2	1021	844	1525	1,5	3,85	0,55	174	305	150	1366	2965	2009	956	685	1213	1231
16-4F-2	1035	858	1538	2,2	4,34	0,55	174	305	150	1379	2965	2009	956	685	1213	1231
16-5E-2	1144	967	1683	1,5	3,73	0,55	212	305	150	1524	3156	2200	956	875	1213	1231
16-5F-2	1157	980	1697	2,2	4,21	0,55	212	305	150	1538	3156	2200	956	875	1213	1231

† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump

* Units with Series Flow piping configuration. These units are only available with Series Flow and will require crossover piping which can either be supplied by the factory or by others.


** Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

^Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

ENGINEERING DATA & DIMENSIONS

ATW

MODELS: 24-3G TO 48-5G



Note: The number of coil connections doubles when the flow rate exceeds 28 l/s on Models ATW 24-3G thru ATW 48-5G.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)				
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	L
24-3G	1185	980	1875	4	6,7	0,55	197	(3) 455	150	1695	2619	1819	800	496	1826
24-4G	1350	1150	2100	4	6,5	0,55	254	(3) 455	150	1925	2810	2010	800	686	1826
24-5G	1540	1335	2340	4	6,3	0,55	314	(3) 455	150	2165	3000	2200	800	876	1826
36-3F	1730	1445	2725	(2) 2,2	9,6	0,75	288	(3) 680	150	2470	2619	1819	800	496	2731
36-4F	1980	1695	3060	(2) 2,2	9,3	0,75	375	(3) 680	150	2810	2810	2010	800	686	2731
36-5F	2245	1965	3420	(2) 2,2	8,9	0,75	462	(3) 680	150	3165	3000	2200	800	876	2731
48-3F	2115	1760	3430	(2) 2,2	11,8	1,1	379	(3) 870	200	3100	2619	1819	800	496	3651
48-3G	2130	1780	3445	(2) 4	13,4	1,1	379	(3) 870	200	3115	2619	1819	800	496	3651
48-4G	2470	2115	3900	(2) 4	13,0	1,1	496	(3) 870	200	3570	2810	2010	800	686	3651
48-5G	2830	2475	4380	(2) 4	12,6	1,1	613	(3) 870	200	4050	3000	2200	800	876	3651


† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump

* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

MODELS: 64-3H TO 84-6K



Note: The number of coil connections doubles when the flow rate exceeds 56 l/s on Models ATW 64-3H thru ATW 84-6K.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)				
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	L
64-3H	3055	2465	4605	5,5	15,8	1,5	542	833	200	4115	3232	2007	1226	496	2578
64-3I	3065	2475	4620	7,5	17,3	1,5	542	833	200	4130	3232	2007	1226	496	2578
64-4H	3490	2900	5205	5,5	15,3	1,5	707	833	200	4715	3423	2197	1226	686	2578
64-4I	3500	2910	5215	7,5	16,7	1,5	707	833	200	4725	3423	2197	1226	686	2578
64-5I	3975	3385	5855	7,5	16,2	1,5	872	833	200	5365	3613	2388	1226	876	2578
64-5J	4000	3410	5885	11,0	18,2	1,5	872	833	200	5395	3613	2388	1226	876	2578
64-6I	4440	3850	6485	7,5	15,8	1,5	1038	833	200	5995	3804	2578	1226	1066	2578
64-6J	4470	3880	6515	11,0	17,6	1,5	1038	833	200	6025	3804	2578	1226	1066	2578
72-3H	3440	2805	5120	5,5	16,8	1,5	576	910	200	4570	3439	2121	1318	496	2731
72-3I	3450	2815	5135	7,5	18,5	1,5	576	910	200	4585	3439	2121	1318	496	2731
72-4H	3930	3295	5790	5,5	16,4	1,5	751	910	200	5240	3629	2311	1318	686	2731
72-4I	3940	3305	5800	7,5	18,0	1,5	751	910	200	5255	3629	2311	1318	686	2731
72-4J	3975	3340	5835	11,0	20,2	1,5	751	910	200	5285	3629	2311	1318	686	2731
72-5H	4460	3825	6495	5,5	15,9	1,5	926	910	200	5945	3820	2502	1318	876	2731
72-5I	4470	3835	6510	7,5	17,5	1,5	926	910	200	5960	3820	2502	1318	876	2731
72-5J	4505	3870	6540	11,0	19,5	1,5	926	910	200	5990	3820	2502	1318	876	2731
72-6H	4980	4345	7190	5,5	15,4	1,5	1102	910	200	6640	4010	2692	1318	1066	2731
72-6I	4995	4360	7205	7,5	16,9	1,5	1102	910	200	6655	4010	2692	1318	1066	2731
72-6J	5025	4390	7235	11,0	18,9	1,5	1102	910	200	6685	4010	2692	1318	1066	2731
72-6K	5050	4415	7255	15,0	20,5	1,5	1102	910	200	6710	4010	2692	1318	1066	2731
84-3I	3960	3225	5940	7,5	20,5	2,2	666	1060	250	5280	3439	2121	1318	496	3188
84-3J	3990	3255	5970	11,0	23,2	2,2	666	1060	250	5310	3439	2121	1318	496	3188
84-4I	4525	3790	6710	7,5	19,9	2,2	871	1060	250	6050	3629	2311	1318	686	3188
84-4J	4560	3825	6740	11,0	22,5	2,2	871	1060	250	6085	3629	2311	1318	686	3188
84-5I	5155	4420	7545	7,5	19,4	2,2	1077	1060	250	6885	3820	2502	1318	876	3188
84-5J	5185	4450	7575	11,0	21,9	2,2	1077	1060	250	6915	3820	2502	1318	876	3188
84-5K	5205	4470	7600	15,0	23,7	2,2	1077	1060	250	6940	3820	2502	1318	876	3188
84-6I	5755	5020	8350	7,5	18,8	2,2	1282	1060	250	7695	4010	2692	1318	1066	3188
84-6J	5790	5055	8380	11,0	21,2	2,2	1282	1060	250	7725	4010	2692	1318	1066	3188
84-6K	5810	5075	8405	15,0	23,0	2,2	1282	1060	250	7745	4010	2692	1318	1066	3188

The motors are shipped loose for field mounting.

† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump



* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

^Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.



ENGINEERING DATA & DIMENSIONS



MODELS: 96-3I TO 142-6K



Note: The number of coil connections doubles when the flow rate exceeds 56 l/s on Models ATW 96-3I thru ATW 112-6M.



Note: The number of coil connections doubles when the flow rate exceeds 56 l/s on models ATW 142-3H thru ATW 142-6K.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^a (mm)				
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	L
96-3I	4280	3470	6575	7,5	22,5	2,2	756	1210	250	5840	3439	2121	1318	496	3651
96-3J	4315	3500	6610	11,0	25,6	2,2	756	1210	250	5870	3439	2121	1318	496	3651
96-4I	4950	4135	7480	7,5	21,8	2,2	991	1210	250	6740	3629	2311	1318	686	3651
96-4J	4980	4170	7510	11,0	24,9	2,2	991	1210	250	6770	3629	2311	1318	686	3651
96-4K	5005	4190	7535	15,0	27,0	2,2	991	1210	250	6795	3629	2311	1318	686	3651
96-5I	5615	4805	8380	7,5	21,2	2,2	1227	1210	250	7645	3820	2502	1318	876	3651
96-5J	5645	4835	8415	11,0	24,1	2,2	1227	1210	250	7675	3820	2502	1318	876	3651
96-5K	5670	4860	8435	15,0	26,1	2,2	1227	1210	250	7695	3820	2502	1318	876	3651
96-6I	6320	5505	9320	7,5	20,5	2,2	1462	1210	250	8580	4010	2692	1318	1066	3651
96-6J	6350	5540	9355	11,0	23,4	2,2	1462	1210	250	8615	4010	2692	1318	1066	3651
96-6K	6375	5560	9375	15,0	25,3	2,2	1462	1210	250	8635	4010	2692	1318	1066	3651
96-6L	6385	5575	9390	18,5	27,0	2,2	1462	1210	250	8650	4010	2692	1318	1066	3651
112-3J	4865	3965	7540	11,0	28,6	2,2	876	1365	250	6690	3550	2121	1429	496	4261
112-3K	4890	3985	7560	15,0	31,0	2,2	876	1365	250	6715	3550	2121	1429	496	4261
112-4J	5640	4735	8580	11,0	27,7	2,2	1152	1365	250	7735	3740	2311	1429	686	4261
112-4K	5660	4760	8605	15,0	30,1	2,2	1152	1365	250	7755	3740	2311	1429	686	4261
112-4L	5675	4770	8620	18,5	32,1	2,2	1152	1365	250	7770	3740	2311	1429	686	4261
112-5J	6410	5505	9630	11,0	26,9	2,2	1427	1365	250	8780	3931	2502	1429	876	4261
112-5K	6430	5530	9650	15,0	29,2	2,2	1427	1365	250	8805	3931	2502	1429	876	4261
112-5L	6445	5545	9665	18,5	31,1	2,2	1427	1365	250	8820	3931	2502	1429	876	4261
112-6J	7220	6320	10720	11,0	26,1	2,2	1702	1365	250	9870	4121	2692	1429	1066	4261
112-6K	7245	6340	10740	15,0	28,3	2,2	1702	1365	250	9895	4121	2692	1429	1066	4261
112-6L	7255	6355	10755	18,5	30,1	2,2	1702	1365	250	9905	4121	2692	1429	1066	4261
112-6M	7265	6365	10765	22,0	31,7	2,2	1702	1365	250	9915	4121	2692	1429	1066	4261
142-3H	6540	5300	9990	(2)5,5	33,7	4,0	1117	1815	300	8890	3651	2121	1530	496	5486
142-3I	6570	5325	10015	(2)7,5	37,0	4,0	1117	1815	300	8920	3651	2121	1530	496	5486
142-4H	7550	6305	11355	(2)5,5	32,7	4,0	1472	1815	300	10255	3842	2311	1530	686	5486
142-4I	7575	6330	11380	(2)7,5	36,0	4,0	1472	1815	300	10285	3842	2311	1530	686	5486
142-4J	7640	6395	11445	(2)11,0	40,3	4,0	1472	1815	300	10345	3842	2311	1530	686	5486
142-5H	8530	7290	12690	(2)5,5	31,7	4,0	1827	1815	300	11595	4032	2502	1530	876	5486
142-5I	8560	7315	12720	(2)7,5	34,9	4,0	1827	1815	300	11620	4032	2502	1530	876	5486
142-5J	8625	7380	12780	(2)11,0	39,1	4,0	1827	1815	300	11685	4032	2502	1530	876	5486
142-6H	9585	8340	14100	(2)5,5	30,7	4,0	2183	1815	300	13000	4223	2692	1530	1066	5486
142-6I	9610	8370	14125	(2)7,5	33,9	4,0	2183	1815	300	13025	4223	2692	1530	1066	5486
142-6J	9675	8430	14190	(2)11,0	37,9	4,0	2183	1815	300	13090	4223	2692	1530	1066	5486
142-6K	9720	8480	14235	(2)15,0	41,1	4,0	2183	1815	300	13135	4223	2692	1530	1066	5486



The motors are shipped loose for field mounting.

† Heaviest section is the coil / fan section †† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump


* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

^a Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

MODELS: 166-3I TO 224-6M



Note: The number of coil connections doubles when the flow rate exceeds 56 l/s on Models ATW 166-3I thru ATW 166-6K.



Note: The number of coil connections doubles when the flow rate exceeds 112 l/s on Models ATW 192-3I thru ATW 224-6M.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)				
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	L
166-3I	7390	6025	11455	(2)7,5	41,2	5,5	1297	2120	300	10170	3651	2121	1530	496	6401
166-3J	7455	6085	11515	(2)11,0	46,6	5,5	1297	2120	300	10235	3651	2121	1530	496	6401
166-4I	8555	7190	13035	(2)7,5	40,0	5,5	1712	2120	300	11755	3842	2311	1530	686	6401
166-4J	8620	7255	13100	(2)11,0	45,2	5,5	1712	2120	300	11815	3842	2311	1530	686	6401
166-5I	9700	8330	14590	(2)7,5	38,8	5,5	2128	2120	300	13310	4032	2502	1530	876	6401
166-5J	9760	8395	14655	(2)11,0	43,9	5,5	2128	2120	300	13370	4032	2502	1530	876	6401
166-5K	9805	8440	14700	(2)15,0	47,6	5,5	2128	2120	300	13415	4032	2502	1530	876	6401
166-6I	10910	9545	16220	(2)7,5	37,6	5,5	2543	2120	300	14935	4223	2692	1530	1066	6401
166-6J	10970	9605	16285	(2)11,0	42,5	5,5	2543	2120	300	15000	4223	2692	1530	1066	6401
166-6K	11020	9650	16330	(2)15,0	46,1	5,5	2543	2120	300	15045	4223	2692	1530	1066	6401
192-3I	8565	3470	13155	(2)7,5	45,0	(2) 2,2	1512	2425	(2) 250	11675	3651	2121	1530	496	7366
192-3J	8625	3500	13220	(2)11,0	51,2	(2) 2,2	1512	2425	(2) 250	11740	3651	2121	1530	496	7366
192-4I	9895	4135	14955	(2)7,5	43,7	(2) 2,2	1983	2425	(2) 250	13475	3842	2311	1530	686	7366
192-4J	9960	4170	15020	(2)11,0	49,7	(2) 2,2	1983	2425	(2) 250	13540	3842	2311	1530	686	7366
192-4K	10005	4190	15065	(2)15,0	53,9	(2) 2,2	1983	2425	(2) 250	13585	3842	2311	1530	686	7366
192-5I	11230	4805	16760	(2)7,5	42,4	(2) 2,2	2453	2425	(2) 250	15280	4032	2502	1530	876	7366
192-5J	11295	4835	16825	(2)11,0	48,2	(2) 2,2	2453	2425	(2) 250	15345	4032	2502	1530	876	7366
192-5K	11340	4860	16870	(2)15,0	52,3	(2) 2,2	2453	2425	(2) 250	15390	4032	2502	1530	876	7366
192-6I	12635	5505	18640	(2)7,5	41,1	(2) 2,2	2924	2425	(2) 250	17160	4223	2692	1530	1066	7366
192-6J	12700	5540	18700	(2)11,0	46,7	(2) 2,2	2924	2425	(2) 250	17225	4223	2692	1530	1066	7366
192-6K	12745	5560	18745	(2)15,0	50,7	(2) 2,2	2924	2425	(2) 250	17270	4223	2692	1530	1066	7366
192-6L	12775	5575	18775	(2)18,5	53,9	(2) 2,2	2924	2425	(2) 250	17295	4223	2692	1530	1066	7366
224-3J	9735	3965	15075	(2)11,0	57,1	(2) 2,2	1753	2725	(2) 250	13375	3804	2121	1683	496	8585
224-3K	9780	3985	15120	(2)15,0	62,0	(2) 2,2	1753	2725	(2) 250	13420	3804	2121	1683	496	8585
224-4J	11275	4735	17165	(2)11,0	55,4	(2) 2,2	2303	2725	(2) 250	15465	3994	2311	1683	686	8585
224-4K	11320	4760	17210	(2)15,0	60,2	(2) 2,2	2303	2725	(2) 250	15515	3994	2311	1683	686	8585
224-4L	11350	4770	17235	(2)18,5	64,1	(2) 2,2	2303	2725	(2) 250	15540	3994	2311	1683	686	8585
224-5J	12820	5505	19255	(2)11,0	53,7	(2) 2,2	2854	2725	(2) 250	17560	4185	2502	1683	876	8585
224-5K	12865	5530	19300	(2)15,0	58,4	(2) 2,2	2854	2725	(2) 250	17605	4185	2502	1683	876	8585
224-5L	12890	5545	19330	(2)18,5	62,2	(2) 2,2	2854	2725	(2) 250	17630	4185	2502	1683	876	8585
224-6J	14440	6320	21430	(2)11,0	52,1	(2) 2,2	3405	2725	(2) 250	19735	4375	2692	1683	1066	8585
224-6K	14490	6340	21480	(2)15,0	56,6	(2) 2,2	3405	2725	(2) 250	19780	4375	2692	1683	1066	8585
224-6L	14515	6355	21505	(2)18,5	60,2	(2) 2,2	3405	2725	(2) 250	19810	4375	2692	1683	1066	8585
224-6M	14535	6365	21525	(2)22,0	63,4	(2) 2,2	3405	2725	(2) 250	19825	4375	2692	1683	1066	8585

The motors are shipped loose for field mounting.

† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump


* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

ENGINEERING DATA & DIMENSIONS



MODELS: 284-3H TO 332-6K



Note: The number of coil connections doubles when the flow rate exceeds 112 l/s on Models ATW 284-3H thru ATW 332-6K.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)					
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	P	L
284-3H	13080	5300	19975	(4)5,5	67,3	(2) 4,0	2233	3635	(2) 300	17780	3804	2121	1683	496	485	11036
284-3I	13135	5325	20030	(4)7,5	74,1	(2) 4,0	2233	3635	(2) 300	17835	3804	2121	1683	496	485	11036
284-4H	15095	6305	22700	(4)5,5	65,4	(2) 4,0	2944	3635	(2) 300	20505	3994	2311	1683	686	485	11036
284-4I	15150	6330	22755	(4)7,5	71,9	(2) 4,0	2944	3635	(2) 300	20560	3994	2311	1683	686	485	11036
284-4J	15275	6395	22885	(4)11,0	80,6	(2) 4,0	2944	3635	(2) 300	20690	3994	2311	1683	686	485	11036
284-5H	17065	7290	25385	(4)5,5	63,5	(2) 4,0	3655	3635	(2) 300	23190	4185	2502	1683	876	485	11036
284-5I	17120	7315	25435	(4)7,5	69,9	(2) 4,0	3655	3635	(2) 300	23240	4185	2502	1683	876	485	11036
284-5J	17245	7380	25565	(4)11,0	78,2	(2) 4,0	3655	3635	(2) 300	23370	4185	2502	1683	876	485	11036
284-6H	19170	8340	28195	(4)5,5	61,4	(2) 4,0	4366	3635	(2) 300	26000	4375	2692	1683	1066	485	11036
284-6I	19225	8370	28250	(4)7,5	67,7	(2) 4,0	4366	3635	(2) 300	26055	4375	2692	1683	1066	485	11036
284-6J	19350	8430	28375	(4)11,0	75,8	(2) 4,0	4366	3635	(2) 300	26180	4375	2692	1683	1066	485	11036
284-6K	19440	8480	28465	(4)15,0	82,1	(2) 4,0	4366	3635	(2) 300	26270	4375	2692	1683	1066	485	11036
332-3I	14725	5995	22850	(4)7,5	82,4	(2) 5,5	2594	4240	(2) 300	20285	3804	2121	1683	496	660	12866
332-3J	14780	6025	22905	(4)11,0	93,2	(2) 5,5	2594	4240	(2) 300	20340	3804	2121	1683	496	660	12866
332-4I	17055	7160	26015	(4)7,5	80,0	(2) 5,5	3425	4240	(2) 300	23445	3994	2311	1683	686	660	12866
332-4J	17110	7190	26070	(4)11,0	90,5	(2) 5,5	3425	4240	(2) 300	23500	3994	2311	1683	686	660	12866
332-5I	19340	8305	29130	(4)7,5	77,6	(2) 5,5	4255	4240	(2) 300	26560	4185	2502	1683	876	660	12866
332-5J	19395	8330	29185	(4)11,0	87,8	(2) 5,5	4255	4240	(2) 300	26615	4185	2502	1683	876	660	12866
332-5K	19525	8395	29310	(4)15,0	95,1	(2) 5,5	4255	4240	(2) 300	26745	4185	2502	1683	876	660	12866
332-6I	21765	9515	32380	(4)7,5	75,2	(2) 5,5	5086	4240	(2) 300	29815	4375	2692	1683	1066	660	12866
332-6J	21820	9545	32435	(4)11,0	85,0	(2) 5,5	5086	4240	(2) 300	29870	4375	2692	1683	1066	660	12866
332-6K	21945	9605	32565	(4)15,0	92,1	(2) 5,5	5086	4240	(2) 300	29995	4375	2692	1683	1066	660	12866

The motors are shipped loose for field mounting.



† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump

* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

MODELS: 166W-3I TO 224W-6L



Note: The number of coil connections doubles when the flow rate exceeds 112 l/s on Models ATW 166W-3I thru ATW 224W-6L.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)				
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	L
166W-3I	7895	3210	11850	(2)7,5	41,1	(2) 2,2	1332	2120	(2) 250	10530	3651	2121	1530	496	3188
166W-3J	7920	3225	11875	(2)11,0	46,5	(2) 2,2	1332	2120	(2) 250	10560	3651	2121	1530	496	3188
166W-4I	9025	3780	13390	(2)7,5	39,9	(2) 2,2	1743	2120	(2) 250	12075	3842	2311	1530	686	3188
166W-4J	9055	3790	13415	(2)11,0	45,0	(2) 2,2	1743	2120	(2) 250	12100	3842	2311	1530	686	3188
166W-5I	10280	4405	15055	(2)7,5	38,7	(2) 2,2	2153	2120	(2) 250	13740	4032	2502	1530	876	3188
166W-5J	10305	4420	15080	(2)11,0	43,7	(2) 2,2	2153	2120	(2) 250	13765	4032	2502	1530	876	3188
166W-5K	10370	4450	15145	(2)15,0	47,4	(2) 2,2	2153	2120	(2) 250	13830	4032	2502	1530	876	3188
166W-6I	11485	5010	16670	(2)7,5	37,5	(2) 2,2	2564	2120	(2) 250	15355	4223	2692	1530	1066	3188
166W-6J	11510	5020	16695	(2)11,0	42,4	(2) 2,2	2564	2120	(2) 250	15380	4223	2692	1530	1066	3188
166W-6K	11575	5055	16760	(2)15,0	45,9	(2) 2,2	2564	2120	(2) 250	15445	4223	2692	1530	1066	3188
192W-3I	8565	3470	13155	(2)7,5	45,0	(2) 2,2	1512	2425	(2) 250	11675	3651	2121	1530	496	3651
192W-3J	8625	3500	13220	(2)11,0	51,2	(2) 2,2	1512	2425	(2) 250	11740	3651	2121	1530	496	3651
192W-4I	9895	4135	14955	(2)7,5	43,7	(2) 2,2	1983	2425	(2) 250	13475	3842	2311	1530	686	3651
192W-4J	9960	4170	15020	(2)11,0	49,7	(2) 2,2	1983	2425	(2) 250	13540	3842	2311	1530	686	3651
192W-4K	10005	4190	15065	(2)15,0	53,9	(2) 2,2	1983	2425	(2) 250	13585	3842	2311	1530	686	3651
192W-5I	11230	4805	16760	(2)7,5	42,4	(2) 2,2	2453	2425	(2) 250	15280	4032	2502	1530	876	3651
192W-5J	11295	4835	16825	(2)11,0	48,2	(2) 2,2	2453	2425	(2) 250	15345	4032	2502	1530	876	3651
192W-5K	11340	4860	16870	(2)15,0	52,3	(2) 2,2	2453	2425	(2) 250	15390	4032	2502	1530	876	3651
192W-6I	12635	5505	18640	(2)7,5	41,1	(2) 2,2	2924	2425	(2) 250	17160	4223	2692	1530	1066	3651
192W-6J	12700	5540	18700	(2)11,0	46,7	(2) 2,2	2924	2425	(2) 250	17225	4223	2692	1530	1066	3651
192W-6K	12745	5560	18745	(2)15,0	50,7	(2) 2,2	2924	2425	(2) 250	17270	4223	2692	1530	1066	3651
192W-6L	12775	5575	18775	(2)18,5	53,9	(2) 2,2	2924	2425	(2) 250	17295	4223	2692	1530	1066	3651
224W-3J	9735	3965	15075	(2)11,0	57,1	(2) 2,2	1753	2725	(2) 250	13375	3804	2121	1683	496	4261
224W-3K	9780	3985	15120	(2)15,0	62,0	(2) 2,2	1753	2725	(2) 250	13420	3804	2121	1683	496	4261
224W-4J	11275	4735	17165	(2)11,0	55,4	(2) 2,2	2303	2725	(2) 250	15465	3994	2311	1683	686	4261
224W-4K	11320	4760	17210	(2)15,0	60,2	(2) 2,2	2303	2725	(2) 250	15515	3994	2311	1683	686	4261
224W-4L	11350	4770	17235	(2)18,5	64,1	(2) 2,2	2303	2725	(2) 250	15540	3994	2311	1683	686	4261
224W-5J	12820	5505	19255	(2)11,0	53,7	(2) 2,2	2854	2725	(2) 250	17560	4185	2502	1683	876	4261
224W-5K	12865	5530	19300	(2)15,0	58,4	(2) 2,2	2854	2725	(2) 250	17605	4185	2502	1683	876	4261
224W-5L	12890	5545	19330	(2)18,5	62,2	(2) 2,2	2854	2725	(2) 250	17630	4185	2502	1683	876	4261
224W-6J	14440	6320	21430	(2)11,0	52,1	(2) 2,2	3405	2725	(2) 250	19735	4375	2692	1683	1066	4261
224W-6K	14490	6340	21480	(2)15,0	56,6	(2) 2,2	3405	2725	(2) 250	19780	4375	2692	1683	1066	4261
224W-6L	14515	6355	21505	(2)18,5	60,2	(2) 2,2	3405	2725	(2) 250	19810	4375	2692	1683	1066	4261

The motors are shipped loose for field mounting.

† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump


* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

ENGINEERING DATA & DIMENSIONS



MODELS: 120-3J TO 180-6N



Note: The number of coil connections doubles when the flow rate exceeds 56 l/s on Models ATW 120-3J thru ATW 180-6N.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)				
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	A	P	L
120-3J	5620	4465	9025	11	30,1	4	959	1590	300	7425	4112	2530	565	485	3651
120-3K	5645	4485	9050	15	32,8	4	959	1590	300	7450	4112	2530	565	485	3651
120-3L	5665	4510	9070	18,5	34,9	4	959	1590	300	7470	4112	2530	565	485	3651
120-4J	6475	5315	10180	11	29,2	4	1258	1590	300	8575	4328	2746	781	485	3651
120-4K	6495	5340	10200	15	31,9	4	1258	1590	300	8600	4328	2746	781	485	3651
120-4L	6520	5360	10225	18,5	33,9	4	1258	1590	300	8625	4328	2746	781	485	3651
120-5J	7280	6125	11280	11	28,3	4	1557	1590	300	9680	4543	2962	997	485	3651
120-5K	7305	6145	11305	15	30,9	4	1557	1590	300	9700	4543	2962	997	485	3651
120-5L	7325	6170	11325	18,5	32,9	4	1557	1590	300	9725	4543	2962	997	485	3651
120-5M	7370	6215	11370	22	34,6	4	1557	1590	300	9770	4543	2962	997	485	3651
120-6J	8150	6995	12450	11	27,5	4	1855	1590	300	10850	4759	3178	1213	485	3651
120-6K	8175	7015	12475	15	29,9	4	1855	1590	300	10875	4759	3178	1213	485	3651
120-6L	8195	7040	12495	18,5	31,9	4	1855	1590	300	10895	4759	3178	1213	485	3651
120-6M	8240	7085	12540	22	33,5	4	1855	1590	300	10940	4759	3178	1213	485	3651
180-3J	8040	6335	13155	11	39,5	5,5	1417	2385	300	10745	4112	2530	565	660	5486
180-3K	8060	6360	13175	15	43,5	5,5	1417	2385	300	10770	4112	2530	565	660	5486
180-3L	8085	6380	13200	18,5	46,8	5,5	1417	2385	300	10790	4112	2530	565	660	5486
180-3M	8130	6425	13245	22	49,3	5,5	1417	2385	300	10835	4112	2530	565	660	5486
180-4J	9310	7605	14875	11	38,4	5,5	1868	2385	300	12465	4328	2746	781	660	5486
180-4K	9330	7630	14895	15	42,2	5,5	1868	2385	300	12485	4328	2746	781	660	5486
180-4L	9355	7650	14920	18,5	45,5	5,5	1868	2385	300	12510	4328	2746	781	660	5486
180-4M	9400	7695	14965	22	47,9	5,5	1868	2385	300	12555	4328	2746	781	660	5486
180-4N	9510	7810	15075	30	51,9	5,5	1868	2385	300	12670	4328	2746	781	660	5486
180-5J	10535	8835	16555	11	37,2	5,5	2320	2385	300	14150	4543	2962	997	660	5486
180-5K	10560	8860	16580	15	40,9	5,5	2320	2385	300	14170	4543	2962	997	660	5486
180-5L	10580	8880	16600	18,5	44,1	5,5	2320	2385	300	14195	4543	2962	997	660	5486
180-5M	10630	8925	16645	22	46,5	5,5	2320	2385	300	14240	4543	2962	997	660	5486
180-5N	10740	9040	16760	30	50,4	5,5	2320	2385	300	14350	4543	2962	997	660	5486
180-6J	11830	10130	18300	11	36,1	5,5	2771	2385	300	15890	4759	3178	1213	660	5486
180-6K	11850	10150	18320	15	39,7	5,5	2771	2385	300	15910	4759	3178	1213	660	5486
180-6L	11875	10175	18345	18,5	42,7	5,5	2771	2385	300	15935	4759	3178	1213	660	5486
180-6M	11920	10220	18390	22	45,0	5,5	2771	2385	300	15980	4759	3178	1213	660	5486
180-6N	12035	10335	18500	30	48,8	5,5	2771	2385	300	16095	4759	3178	1213	660	5486

The motors are shipped loose for field mounting.


† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump

* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

MODELS: 241-3J TO 360-6N



Note: The number of coil connections doubles when the flow rate exceeds 112 l/s on Models ATW 241-3J thru ATW 241-6M and ATW 360-3J thru ATW 360-6N.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)				
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	A	P	L
241-3J	11360	4465	18170	(2) 11	60,2	(2) 4	1918	3180	(2) 300	14970	4416	2530	565	485	7366
241-3K	11405	4485	18215	(2) 15	65,6	(2) 4	1918	3180	(2) 300	15015	4416	2530	565	485	7366
241-3L	11450	4510	18260	(2) 18,5	69,8	(2) 4	1918	3180	(2) 300	15060	4416	2530	565	485	7366
241-4J	13065	5315	20475	(2) 11	58,4	(2) 4	2515	3180	(2) 300	17275	4632	2746	781	485	7366
241-4K	13110	5340	20520	(2) 15	63,7	(2) 4	2515	3180	(2) 300	17320	4632	2746	781	485	7366
241-4L	13155	5360	20565	(2) 18,5	67,8	(2) 4	2515	3180	(2) 300	17365	4632	2746	781	485	7366
241-5J	14680	6125	22680	(2) 11	56,7	(2) 4	3113	3180	(2) 300	19475	4848	2962	997	485	7366
241-5K	14725	6145	22725	(2) 15	61,8	(2) 4	3113	3180	(2) 300	19525	4848	2962	997	485	7366
241-5L	14770	6170	22770	(2) 18,5	65,8	(2) 4	3113	3180	(2) 300	19570	4848	2962	997	485	7366
241-5M	14860	6215	22860	(2) 22	69,2	(2) 4	3113	3180	(2) 300	19660	4848	2962	997	485	7366
241-6J	16420	6995	25020	(2) 11	54,9	(2) 4	3711	3180	(2) 300	21820	5064	3178	1213	485	7366
241-6K	16465	7015	25065	(2) 15	59,9	(2) 4	3711	3180	(2) 300	21865	5064	3178	1213	485	7366
241-6L	16510	7040	25110	(2) 18,5	63,7	(2) 4	3711	3180	(2) 300	21910	5064	3178	1213	485	7366
241-6M	16600	7085	25200	(2) 22	67,1	(2) 4	3711	3180	(2) 300	22000	5064	3178	1213	485	7366
360-3J	16075	6335	26305	(2) 11	79,0	(2) 5,5	2833	4770	(2) 300	21490	4416	2530	565	660	11036
360-3K	16120	6360	26350	(2) 15	87,0	(2) 5,5	2833	4770	(2) 300	21535	4416	2530	565	660	11036
360-3L	16165	6380	26395	(2) 18,5	93,7	(2) 5,5	2833	4770	(2) 300	21580	4416	2530	565	660	11036
360-3M	16255	6425	26485	(2) 22	98,7	(2) 5,5	2833	4770	(2) 300	21675	4416	2530	565	660	11036
360-4J	18615	7605	29740	(2) 11	76,7	(2) 5,5	3736	4770	(2) 300	24930	4632	2746	781	660	11036
360-4K	18660	7630	29785	(2) 15	84,4	(2) 5,5	3736	4770	(2) 300	24975	4632	2746	781	660	11036
360-4L	18705	7650	29835	(2) 18,5	91,0	(2) 5,5	3736	4770	(2) 300	25020	4632	2746	781	660	11036
360-4M	18795	7695	29925	(2) 22	95,8	(2) 5,5	3736	4770	(2) 300	25110	4632	2746	781	660	11036
360-4N	19025	7810	30150	(2) 30	103,8	(2) 5,5	3736	4770	(2) 300	25340	4632	2746	781	660	11036
360-5J	21075	8835	33110	(2) 11	74,4	(2) 5,5	4639	4770	(2) 300	28295	4848	2962	997	660	11036
360-5K	21120	8860	33155	(2) 15	81,9	(2) 5,5	4639	4770	(2) 300	28340	4848	2962	997	660	11036
360-5L	21165	8880	33200	(2) 18,5	88,2	(2) 5,5	4639	4770	(2) 300	28385	4848	2962	997	660	11036
360-5M	21255	8925	33290	(2) 22	92,9	(2) 5,5	4639	4770	(2) 300	28475	4848	2962	997	660	11036
360-5N	21480	9040	33515	(2) 30	100,7	(2) 5,5	4639	4770	(2) 300	28705	4848	2962	997	660	11036
360-6J	23660	10130	36590	(2) 11	72,1	(2) 5,5	5542	4770	(2) 300	31780	5064	3178	1213	660	11036
360-6K	23705	10150	36635	(2) 15	79,4	(2) 5,5	5542	4770	(2) 300	31825	5064	3178	1213	660	11036
360-6L	23750	10175	36680	(2) 18,5	85,5	(2) 5,5	5542	4770	(2) 300	31870	5064	3178	1213	660	11036
360-6M	23840	10220	36775	(2) 22	90,0	(2) 5,5	5542	4770	(2) 300	31960	5064	3178	1213	660	11036
360-6N	24070	10335	37000	(2) 30	97,6	(2) 5,5	5542	4770	(2) 300	32185	5064	3178	1213	660	11036

The motors are shipped loose for field mounting.

† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump


* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

^Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

ENGINEERING DATA & DIMENSIONS



MODELS: 242-3J TO 362-6N



Note: The number of coil connections doubles when the flow rate exceeds 112 l/s on Models ATW 242-3J thru ATW 242-6M and ATW 362-3J thru ATW 362-6N.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)					
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	P	L
242-3J	11250	4465	18060	(2) 11	60,2	(2) 4	1918	3180	(2) 300	14860	4416	2530	1886	565	485	3651
242-3K	11295	4485	18105	(2) 15	65,6	(2) 4	1918	3180	(2) 300	14905	4416	2530	1886	565	485	3651
242-3L	11340	4510	18155	(2) 18,5	69,8	(2) 4	1918	3180	(2) 300	14950	4416	2530	1886	565	485	3651
242-4J	12955	5315	20365	(2) 11	58,4	(2) 4	2515	3180	(2) 300	17165	4632	2746	1886	781	485	3651
242-4K	13000	5340	20410	(2) 15	63,7	(2) 4	2515	3180	(2) 300	17210	4632	2746	1886	781	485	3651
242-4L	13045	5360	20455	(2) 18,5	67,8	(2) 4	2515	3180	(2) 300	17255	4632	2746	1886	781	485	3651
242-5J	14570	6125	22570	(2) 11	56,7	(2) 4	3113	3180	(2) 300	19370	4848	2962	1886	997	485	3651
242-5K	14615	6145	22615	(2) 15	61,8	(2) 4	3113	3180	(2) 300	19415	4848	2962	1886	997	485	3651
242-5L	14660	6170	22660	(2) 18,5	65,8	(2) 4	3113	3180	(2) 300	19460	4848	2962	1886	997	485	3651
242-5M	14750	6215	22750	(2) 22	69,2	(2) 4	3113	3180	(2) 300	19550	4848	2962	1886	997	485	3651
242-6J	16310	6995	24910	(2) 11	54,9	(2) 4	3711	3180	(2) 300	21710	5064	3178	1886	1213	485	3651
242-6K	16355	7015	24955	(2) 15	59,9	(2) 4	3711	3180	(2) 300	21755	5064	3178	1886	1213	485	3651
242-6L	16400	7040	25000	(2) 18,5	63,7	(2) 4	3711	3180	(2) 300	21800	5064	3178	1886	1213	485	3651
242-6M	16495	7085	25095	(2) 22	67,1	(2) 4	3711	3180	(2) 300	21890	5064	3178	1886	1213	485	3651
362-3J	16095	6335	26320	(2) 11	79	(2) 5,5	2833	4770	(2) 300	21510	4721	2530	2191	565	660	5486
362-3K	16140	6360	26365	(2) 15	87	(2) 5,5	2833	4770	(2) 300	21555	4721	2530	2191	565	660	5486
362-3L	16185	6380	26415	(2) 18,5	93,7	(2) 5,5	2833	4770	(2) 300	21600	4721	2530	2191	565	660	5486
362-3M	16275	6425	26505	(2) 22	98,7	(2) 5,5	2833	4770	(2) 300	21690	4721	2530	2191	565	660	5486
362-4J	18635	7605	29760	(2) 11	76,7	(2) 5,5	3736	4770	(2) 300	24950	4937	2746	2191	781	660	5486
362-4K	18680	7630	29805	(2) 15	84,4	(2) 5,5	3736	4770	(2) 300	24995	4937	2746	2191	781	660	5486
362-4L	18725	7650	29850	(2) 18,5	91	(2) 5,5	3736	4770	(2) 300	25040	4937	2746	2191	781	660	5486
362-4M	18815	7695	29940	(2) 22	95,8	(2) 5,5	3736	4770	(2) 300	25130	4937	2746	2191	781	660	5486
362-4N	19040	7810	30170	(2) 30	103,8	(2) 5,5	3736	4770	(2) 300	25355	4937	2746	2191	781	660	5486
362-5J	21090	8835	33125	(2) 11	74,4	(2) 5,5	4639	4770	(2) 300	28315	5153	2962	2191	997	660	5486
362-5K	21135	8860	33170	(2) 15	81,9	(2) 5,5	4639	4770	(2) 300	28360	5153	2962	2191	997	660	5486
362-5L	21185	8880	33215	(2) 18,5	88,2	(2) 5,5	4639	4770	(2) 300	28405	5153	2962	2191	997	660	5486
362-5M	21275	8925	33305	(2) 22	92,9	(2) 5,5	4639	4770	(2) 300	28495	5153	2962	2191	997	660	5486
362-5N	21500	9040	33535	(2) 30	100,7	(2) 5,5	4639	4770	(2) 300	28720	5153	2962	2191	997	660	5486
362-6J	23680	10130	36610	(2) 11	72,1	(2) 5,5	5542	4770	(2) 300	31795	5369	3178	2191	1213	660	5486
362-6K	23725	10150	36655	(2) 15	79,4	(2) 5,5	5542	4770	(2) 300	31840	5369	3178	2191	1213	660	5486
362-6L	23770	10175	36700	(2) 18,5	85,5	(2) 5,5	5542	4770	(2) 300	31890	5369	3178	2191	1213	660	5486
362-6M	23860	10220	36790	(2) 22	90	(2) 5,5	5542	4770	(2) 300	31980	5369	3178	2191	1213	660	5486
362-6N	24085	10335	37020	(2) 30	97,6	(2) 5,5	5542	4770	(2) 300	32205	5369	3178	2191	1213	660	5486

The motors are shipped loose for field mounting.



† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump

* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

MODELS: 144-3K TO 216-6O



Note: The number of coil connections doubles when the flow rate exceeds 56 l/s on Models ATW 144-3K thru ATW 216-6O.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)					
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	P	L
144-3K	6440	5275	10350	15	37,4	4	1179	1855	300	8575	4112	2530	1581	565	485	3651
144-3L	6465	5300	10375	18,5	39,8	4	1179	1855	300	8600	4112	2530	1581	565	485	3651
144-4K	7475	6310	11755	15	36,3	4	1548	1855	300	9985	4328	2746	1581	781	485	3651
144-4L	7500	6330	11780	18,5	38,7	4	1548	1855	300	10005	4328	2746	1581	781	485	3651
144-4M	7545	6380	11825	22	40,7	4	1548	1855	300	10050	4328	2746	1581	781	485	3651
144-5L	8485	7320	13135	18,5	37,5	4	1917	1855	300	11360	4543	2962	1581	997	485	3651
144-5M	8530	7365	13180	22	39,5	4	1917	1855	300	11410	4543	2962	1581	997	485	3651
144-6M	9605	8435	14620	22	38,2	4	2286	1855	300	12845	4759	3178	1581	1213	485	3651
144-6N	9715	8550	14735	30	41,5	4	2286	1855	300	12960	4759	3178	1581	1213	485	3651
168-3L	7305	5980	11895	18,5	44,5	4	1368	2160	300	9840	4264	2530	1734	565	485	4261
168-3M	7335	6010	11925	22	46,8	4	1368	2160	300	9870	4264	2530	1734	565	485	4261
168-4L	8525	7200	13545	18,5	43,2	4	1799	2160	300	11490	4480	2746	1734	781	485	4261
168-4M	8555	7230	13575	22	45,5	4	1799	2160	300	11520	4480	2746	1734	781	485	4261
168-5M	9690	8365	15140	22	44,1	4	2231	2160	300	13085	4696	2962	1734	997	485	4261
168-5N	9805	8480	15260	30	47,8	4	2231	2160	300	13205	4696	2962	1734	997	485	4261
168-6M	11050	9725	16935	22	42,7	4	2662	2160	300	14880	4912	3178	1734	1213	485	4261
168-6N	11165	9845	17050	30	46,3	4	2662	2160	300	14995	4912	3178	1734	1213	485	4261
216-3L	9165	7440	15030	18,5	54,5	5,5	1744	2725	300	12350	4416	2530	1886	565	660	5486
216-3M	9210	7490	15080	22	57,9	5,5	1744	2725	300	12400	4416	2530	1886	565	660	5486
216-4L	10720	8995	17145	18,5	52,9	5,5	2302	2725	300	14465	4632	2746	1886	781	660	5486
216-4M	10770	9045	17195	22	56,2	5,5	2302	2725	300	14515	4632	2746	1886	781	660	5486
216-4N	10885	9165	17315	30	61	5,5	2302	2725	300	14635	4632	2746	1886	781	660	5486
216-5M	12265	10540	19245	22	54,5	5,5	2859	2725	300	16565	4848	2962	1886	997	660	5486
216-5N	12385	10660	19365	30	59,2	5,5	2859	2725	300	16585	4848	2962	1886	997	660	5486
216-6N	13920	12195	21460	30	57,4	5,5	3416	2725	300	18780	5064	3178	1886	1213	660	5486
216-6O	13950	12225	21485	37	61,1	5,5	3416	2725	300	18805	5064	3178	1886	1213	660	5486

The motors are shipped loose for field mounting.

† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump



* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

ENGINEERING DATA & DIMENSIONS



MODELS: 286-3K TO 430-60



Note: The number of coil connections doubles when the flow rate exceeds 112 l/s on Models ATW 286-3K thru ATW 430-60.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)					
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	P	L
286-3K	12880	5275	20700	(2) 15	74,7	(2) 4	2359	3710	(2) 300	17155	4416	2530	1886	565	485	7366
286-3L	12925	5300	20745	(2) 18,5	79,6	(2) 4	2359	3710	(2) 300	17200	4416	2530	1886	565	485	7366
286-4L	14995	6330	23555	(2) 18,5	77,3	(2) 4	3096	3710	(2) 300	20010	4632	2746	1886	781	485	7366
286-4M	15085	6380	23645	(2) 22	81,4	(2) 4	3096	3710	(2) 300	20100	4632	2746	1886	781	485	7366
286-5L	16975	7320	26270	(2) 18,5	75,0	(2) 4	3834	3710	(2) 300	22720	4848	2962	1886	997	485	7366
286-5M	17065	7365	26360	(2) 22	78,9	(2) 4	3834	3710	(2) 300	22810	4848	2962	1886	997	485	7366
286-6M	19205	8435	29240	(2) 22	76,5	(2) 4	4572	3710	(2) 300	25690	5064	3178	1886	1213	485	7366
286-6N	19430	8550	29465	(2) 30	82,9	(2) 4	4572	3710	(2) 300	25920	5064	3178	1886	1213	485	7366
334-3L	14605	5980	23780	(2) 18,5	89,0	(2) 4	2736	4315	(2) 300	19670	4721	2530	2191	565	485	8585
334-3M	14670	6010	23845	(2) 22	93,7	(2) 4	2736	4315	(2) 300	19735	4721	2530	2191	565	485	8585
334-4L	17045	7200	27090	(2) 18,5	86,4	(2) 4	3599	4315	(2) 300	22980	4937	2746	2191	781	485	8585
334-4M	17110	7230	27150	(2) 22	90,9	(2) 4	3599	4315	(2) 300	23040	4937	2746	2191	781	485	8585
334-5M	19375	8365	30280	(2) 22	88,2	(2) 4	4462	4315	(2) 300	26170	5153	2962	2191	997	485	8585
334-5N	19615	8480	30520	(2) 30	95,6	(2) 4	4462	4315	(2) 300	26410	5153	2962	2191	997	485	8585
334-6M	22100	9725	33865	(2) 22	85,5	(2) 4	5325	4315	(2) 300	29755	5369	3178	2191	1213	485	8585
334-6N	22335	9845	34100	(2) 30	92,7	(2) 4	5325	4315	(2) 300	29990	5369	3178	2191	1213	485	8585
430-3L	18325	7440	30060	(2) 18,5	109,0	(2) 5,5	3489	5450	(2) 300	24700	4721	2530	2191	565	660	11036
430-3M	18425	7490	30160	(2) 22	115,8	(2) 5,5	3489	5450	(2) 300	24800	4721	2530	2191	565	660	11036
430-4L	21435	8995	34285	(2) 18,5	105,8	(2) 5,5	4603	5450	(2) 300	28925	4937	2746	2191	781	660	11036
430-4M	21535	9045	34385	(2) 22	112,4	(2) 5,5	4603	5450	(2) 300	29025	4937	2746	2191	781	660	11036
430-4N	21770	9165	34625	(2) 30	122,0	(2) 5,5	4603	5450	(2) 300	29260	4937	2746	2191	781	660	11036
430-5M	24530	10540	38490	(2) 22	109,1	(2) 5,5	5717	5450	(2) 300	33130	5153	2962	2191	997	660	11036
430-5N	24765	10660	38730	(2) 30	118,4	(2) 5,5	5717	5450	(2) 300	33365	5153	2962	2191	997	660	11036
430-6N	27840	12195	42920	(2) 30	114,7	(2) 5,5	6831	5450	(2) 300	37555	5369	3178	2191	1213	660	11036
430-6O	27895	12225	42975	(2) 37	122,1	(2) 5,5	6831	5450	(2) 300	37610	5369	3178	2191	1213	660	11036

The motors are shipped loose for field mounting.


† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump

* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

MODELS: 290-3K TO 434-60



Note: The number of coil connections doubles when the flow rate exceeds 112 l/s on Models ATW 290-3K thru ATW 434-60.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)					
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	P	L
290-3K	12880	5275	20700	(2) 15	74,7	(2) 4	2359	3709	(2) 300	17155	4416	2530	1886	565	485	3651
290-3L	12925	5300	20745	(2) 18,5	79,6	(2) 4	2359	3709	(2) 300	17200	4416	2530	1886	565	485	3651
290-4L	14995	6330	23555	(2) 18,5	77,3	(2) 4	3096	3709	(2) 300	20010	4632	2746	1886	781	485	3651
290-4M	15085	6380	23645	(2) 22	81,4	(2) 4	3096	3709	(2) 300	20100	4632	2746	1886	781	485	3651
290-5L	16975	7320	26270	(2) 18,5	75,0	(2) 4	3834	3709	(2) 300	22720	4848	2962	1886	997	485	3651
290-5M	17065	7365	26360	(2) 22	78,9	(2) 4	3834	3709	(2) 300	22810	4848	2962	1886	997	485	3651
290-6M	19205	8435	29240	(2) 22	76,5	(2) 4	4572	3709	(2) 300	25690	5064	3178	1886	1213	485	3651
290-6N	19430	8550	29465	(2) 30	82,9	(2) 4	4572	3709	(2) 300	25920	5064	3178	1886	1213	485	3651
338-3L	14605	5980	23780	(2) 18,5	89,0	(2) 4	2736	4315	(2) 300	19670	4721	2530	2191	565	485	4261
338-3M	14670	6010	23845	(2) 22	93,7	(2) 4	2736	4315	(2) 300	19735	4721	2530	2191	565	485	4261
338-4L	17045	7200	27090	(2) 18,5	86,4	(2) 4	3599	4315	(2) 300	22980	4937	2746	2191	781	485	4261
338-4M	17110	7230	27150	(2) 22	90,9	(2) 4	3599	4315	(2) 300	23040	4937	2746	2191	781	485	4261
338-5M	19375	8365	30280	(2) 22	88,2	(2) 4	4462	4315	(2) 300	26170	5153	2962	2191	997	485	4261
338-5N	19615	8480	30520	(2) 30	95,6	(2) 4	4462	4315	(2) 300	26410	5153	2962	2191	997	485	4261
338-6M	22100	9725	33865	(2) 22	85,5	(2) 4	5325	4315	(2) 300	29755	5369	3178	2191	1213	485	4261
338-6N	22335	9845	34100	(2) 30	92,7	(2) 4	5325	4315	(2) 300	29990	5369	3178	2191	1213	485	4261
434-3L	18325	7440	30060	(2) 18,5	109,0	(2) 5,5	3489	5450	(2) 300	24700	5026	2530	2496	565	660	5486
434-3M	18425	7490	30160	(2) 22	115,8	(2) 5,5	3489	5450	(2) 300	24800	5026	2530	2496	565	660	5486
434-4L	21435	8995	34285	(2) 18,5	105,8	(2) 5,5	4603	5450	(2) 300	28925	5242	2746	2496	781	660	5486
434-4M	21535	9045	34385	(2) 22	112,4	(2) 5,5	4603	5450	(2) 300	29025	5242	2746	2496	781	660	5486
434-4N	21770	9165	34625	(2) 30	122,0	(2) 5,5	4603	5450	(2) 300	29260	5242	2746	2496	781	660	5486
434-5M	24530	10540	38490	(2) 22	109,1	(2) 5,5	5717	5450	(2) 300	33130	5458	2962	2496	997	660	5486
434-5N	24765	10660	38730	(2) 30	118,4	(2) 5,5	5717	5450	(2) 300	33365	5458	2962	2496	997	660	5486
434-6N	27840	12195	42920	(2) 30	114,7	(2) 5,5	6831	5450	(2) 300	37555	5674	3178	2496	1213	660	5486
434-6O	27895	12225	42975	(2) 37	122,1	(2) 5,5	6831	5450	(2) 300	37610	5674	3178	2496	1213	660	5486

The motors are shipped loose for field mounting.

† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump



* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

^Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

ENGINEERING DATA & DIMENSIONS

ATW

MODELS: 578-3K TO 866-60



Note: The number of coil connections doubles when the flow rate exceeds 224 l/s on Models ATW 578-3K thru ATW 866-60.

ATW Model No.	Weights (kg)			Fans		Spray Pump kW	Coil Volume (Litres)	Remote Sump††			Dimensions ^Δ (mm)					
	Shipping	Heaviest Section†	Operating	kW	m ³ /s			Liters Req'd*	Conn. Size(mm)	Operating Weight	H	U	E	A	P	L
578-3K	26000	5275	41405	(4) 15	149,5	(4) 4	4718	7420	(4) 300	34310	5026	2530	2496	565	485	7366
578-3L	26090	5300	41495	(4) 18,5	159,3	(4) 4	4718	7420	(4) 300	34400	5026	2530	2496	565	485	7366
578-4K	30135	6310	47015	(4) 15	145,1	(4) 4	6193	7420	(4) 300	39920	5242	2746	2496	781	485	7366
578-4L	30225	6330	47105	(4) 18,5	154,6	(4) 4	6193	7420	(4) 300	40010	5242	2746	2496	781	485	7366
578-4M	30410	6380	47285	(4) 22	162,7	(4) 4	6193	7420	(4) 300	40195	5242	2746	2496	781	485	7366
578-5L	34185	7320	52535	(4) 18,5	150,0	(4) 4	7668	7420	(4) 300	45440	5458	2962	2496	997	485	7366
578-5M	34365	7365	52715	(4) 22	157,9	(4) 4	7668	7420	(4) 300	45620	5458	2962	2496	997	485	7366
578-6M	38645	8435	58475	(4) 22	153,0	(4) 4	9143	7420	(4) 300	51385	5674	3178	2496	1213	485	7366
578-6N	39100	8550	58930	(4) 30	165,8	(4) 4	9143	7420	(4) 300	51835	5674	3178	2496	1213	485	7366
672-3L	29400	5980	47565	(4) 18,5	178,0	(4) 4	5471	8630	(4) 300	39345	5026	2530	2496	565	485	8585
672-3M	29530	6010	47690	(4) 22	187,3	(4) 4	5471	8630	(4) 300	39470	5026	2530	2496	565	485	8585
672-4L	34285	7200	54175	(4) 18,5	172,8	(4) 4	7197	8630	(4) 300	45955	5242	2746	2496	781	485	8585
672-4M	34410	7230	54300	(4) 22	181,9	(4) 4	7197	8630	(4) 300	46080	5242	2746	2496	781	485	8585
672-5M	38945	8365	60560	(4) 22	176,4	(4) 4	8924	8630	(4) 300	52340	5458	2962	2496	997	485	8585
672-5N	39415	8480	61030	(4) 30	191,2	(4) 4	8924	8630	(4) 300	52810	5458	2962	2496	997	485	8585
672-6M	44390	9725	67730	(4) 22	171,0	(4) 4	10650	8630	(4) 300	59510	5674	3178	2496	1213	485	8585
672-6N	44860	9845	68200	(4) 30	185,3	(4) 4	10650	8630	(4) 300	59985	5674	3178	2496	1213	485	8585
866-3L	37040	7440	60335	(4) 18,5	219,7	(4) 5,5	6978	10900	(4) 300	49615	5026	2530	2496	565	660	11036
866-3M	37240	7490	60535	(4) 22	233,4	(4) 5,5	6978	10900	(4) 300	49815	5026	2530	2496	565	660	11036
866-4L	43265	8995	68785	(4) 18,5	213,3	(4) 5,5	9206	10900	(4) 300	58065	5242	2746	2496	781	660	11036
866-4M	43465	9045	68985	(4) 22	226,7	(4) 5,5	9206	10900	(4) 300	58265	5242	2746	2496	781	660	11036
866-5M	49450	10540	77200	(4) 22	219,9	(4) 5,5	11435	10900	(4) 300	66480	5458	2962	2496	997	660	11036
866-5N	49920	10660	77675	(4) 30	238,6	(4) 5,5	11435	10900	(4) 300	66950	5458	2962	2496	997	660	11036
866-6N	56075	12195	86055	(4) 30	231,2	(4) 5,5	13663	10900	(4) 300	75335	5674	3178	2496	1213	660	11036
866-6O	56180	12225	86165	(4) 37	246,1	(4) 5,5	13663	10900	(4) 300	75440	5674	3178	2496	1213	660	11036

The motors are shipped loose for field mounting.

† Heaviest section is the coil / fan section

†† When a remote sump arrangement is selected, the spray pump, suction strainer and associated piping are omitted; the unit is provided with an oversized outlet to facilitate drainage to the remote sump

* Liters shown is water in suspension in unit and piping. Allow for additional water in bottom of remote sump to cover pump suction and strainer during operation. (300mm would normally be sufficient).

Δ Unit dimensions and coil connections may vary slightly from catalog. See factory certified prints for dimensions, quantity of coil connections, and piping configuration.

ATW

RECOMMENDED STEEL SUPPORT


ENGINEERING

The recommended support for EVAPCO Closed Circuit Coolers is structural "I" beams located under the outer flanges and running the entire length of the unit. The unit should be elevated to allow access underneath the unit and to the roof below.


Mounting holes 19 mm in diameter are located in the bottom flanges of the pan section to provide for bolting to the structural steel. (Refer to certified drawings from the factory for bolt hole locations.)

Beams should be level before setting the unit in place. Do not level the unit by shimming between the unit and the structural steel. Dimensions weights and data are subject to change without notice. Refer to the factory certified drawings for exact dimensions.

Plan Views



End Elevations



ATW SUPPORTING STEEL DIMENSIONS

	A	B
ATW 9	908	927
ATW 16	1213	1231
ATW 24	1826	1231
ATW 36	2731	1231
ATW 48	3651	1231
	A	B
ATW 64	2578	2283
ATW 72	2731	2388
ATW 84	3188	2388
ATW 96	3651	2388
ATW 112	4261	2388
ATW 142	5486	2388
ATW 166	6401	2388
	A	B
ATW 120	3651	2991
ATW 180	5486	2991
ATW 241	7366	2991
ATW 360	11036	2991
	A	B
ATW 192	7366	2388
ATW 224	8586	2388
ATW 284	11036	2388
ATW 332	12866	2388
ATW 166W	3188	4906
ATW 192W	3651	4906
ATW 224W	4261	4906
	A	B
ATW 144	3651	3607
ATW 168	4261	3607
ATW 216	5486	3607
ATW 286	7366	3607
ATW 334	8585	3607
ATW 430	11036	3607
	A	B
ATW 242	3651	6112
ATW 362	5486	6112
	A	B
ATW 290	3651	7344
ATW 338	4261	7344
ATW 434	5486	7344
ATW 578	7366	7344
ATW 672	8585	7344
ATW 866	11036	7344

HEAT LOSS DATA, kW



Unit	Standard Unit	Unit with Hood	Hood & Insulation
ATW 9-2	5,6	5,3	3,2
ATW 9-3	7,0	5,9	3,8
ATW 9-4	8,2	6,2	4,1
ATW 9-5	9,4	6,7	4,4
ATW 16-2	10,6	10,0	6,4
ATW 16-3	13,2	11,1	7,0
ATW 16-4	15,8	12,0	7,6
ATW 16-5	17,9	12,6	8,2
ATW 24-3	19,6	16,7	10,6
ATW 24-4	23,7	17,9	11,4
ATW 24-5	26,7	19,0	12,3
ATW 36-3	29,9	21,1	13,5
ATW 36-4	36,0	22,6	14,7
ATW 36-5	40,4	24,3	15,5
ATW 48-3	40,2	27,5	17,6
ATW 48-4	48,4	29,6	19,0
ATW 48-5	54,5	31,7	20,2
ATW 64-3	56,3	31,9	20,5
ATW 64-4	68,0	34,0	21,7
ATW 64-5	76,5	36,0	23,2
ATW 64-6	81,8	37,8	24,3
ATW 72-3	65,6	35,8	22,9
ATW 72-4	79,1	37,8	24,3
ATW 72-5	89,1	40,2	25,8
ATW 72-6	95,0	42,2	27,0
ATW 84-3	76,8	38,7	24,9
ATW 84-4	92,6	41,0	26,4
ATW 84-5	104,3	43,4	27,8
ATW 84-6	111,4	45,7	29,3
ATW 96-3	87,9	41,6	26,7
ATW 96-4	106,4	44,3	28,4
ATW 96-5	119,6	46,9	29,9
ATW 96-6	127,5	49,2	31,7
ATW 112-3	103,2	45,7	29,3
ATW 112-4	124,6	48,4	31,1
ATW 112-5	140,1	51,3	32,8
ATW 112-6	149,2	53,9	34,6
ATW 142-3	133,1	58,6	37,5
ATW 142-4	160,6	61,8	39,6
ATW 142-5	180,8	65,1	41,6
ATW 142-6	192,8	68,6	44,0
ATW 166(W)-3	155,3	64,5	41,3
ATW 166(W)-4	187,9	68,3	43,7
ATW 166(W)-5	212,2	71,8	46,0
ATW 166(W)-6	225,4	75,6	48,4
ATW 192(W)-3	175,8	83,2	53,3
ATW 192(W)-4	212,8	88,5	56,9
ATW 192(W)-5	239,1	93,8	59,8
ATW 192(W)-6	255,0	98,5	63,3
ATW 224(W)-3	206,3	91,4	58,6
ATW 224(W)-4	249,1	96,7	62,1
ATW 224(W)-5	280,2	102,6	65,6
ATW 224(W)-6	298,3	107,9	69,2
ATW 120-3	101,4	47,2	30,2
ATW 120-4	122,5	49,8	31,9
ATW 120-5	137,7	52,5	33,7
ATW 120-6	147,1	55,4	35,5
ATW 180-3	153,3	59,5	38,1
ATW 180-4	184,9	63,0	40,4
ATW 180-5	208,4	66,2	42,5
ATW 180-6	222,1	69,8	44,5
ATW 241-3 & ATW 242-3	202,8	94,7	60,4
ATW 241-4 & ATW 242-4	245,0	99,6	64,2
ATW 241-5 & ATW 242-5	275,5	104,9	67,4
ATW 241-6 & ATW 242-6	294,0	110,8	70,6
ATW 360-3 & ATW 362-3	306,3	119,3	76,5
ATW 360-4 & ATW 362-4	370,1	126,0	80,9
ATW 360-5 & ATW 362-5	416,5	132,5	85,0
ATW 360-6 & ATW 362-6	444,0	139,8	89,4
ATW 144-3	125,1	58,3	37,2
ATW 144-4	151,2	61,5	39,6
ATW 144-5	170,0	64,8	41,6
ATW 144-6	181,4	68,3	43,7
ATW 168-3	146,5	63,3	40,4
ATW 168-4	177,0	66,8	42,8
ATW 168-5	199,0	70,6	45,1
ATW 168-6	212,5	74,1	47,5
ATW 216-3	189,0	73,6	47,2
ATW 216-4	228,3	77,7	49,8
ATW 216-5	257,0	81,8	52,5
ATW 216-6	274,0	86,2	55,1
ATW 286-3 & ATW 290-3	250,3	116,6	74,4
ATW 286-4 & ATW 290-4	302,4	123,1	79,1
ATW 286-5 & ATW 290-5	340,0	129,5	83,2
ATW 286-6 & ATW 290-6	362,8	136,6	87,3
ATW 334-3 & ATW 338-3	293,1	126,6	80,9
ATW 334-4 & ATW 338-4	354,0	133,6	85,6
ATW 334-5 & ATW 338-5	398,0	141,3	90,3
ATW 334-6 & ATW 338-6	425,0	148,3	95,0
ATW 430-3 & ATW 434-3	378,1	147,1	94,4
ATW 430-4 & ATW 434-4	456,6	155,3	99,6
ATW 430-5 & ATW 434-5	514,0	163,5	104,9
ATW 430-6 & ATW 434-6	548,0	172,3	110,2
ATW 578-3	500,6	233,3	148,9
ATW 578-4	604,9	246,2	158,3
ATW 578-5	679,9	259,1	166,5
ATW 578-6	725,6	273,1	174,7
ATW 672-3	586,1	253,2	161,8
ATW 672-4	708,1	267,3	171,2
ATW 672-5	796,0	282,5	180,5
ATW 672-6	849,9	296,6	189,9
ATW 866-3	756,1	294,2	188,7
ATW 866-4	913,2	310,7	199,3
ATW 866-5	1028,1	327,1	209,8
ATW 866-6	1096,1	344,7	220,4

ATW

SPECIFICATIONS

FACTORY FABRICATED INDUCED DRAFT ATW CLOSED CIRCUIT COOLER

General

Furnish and install factory assembled closed circuit cooler of induced draft counterflow design with a horizontal multiple side air entry and a vertical air discharge. The unit shall be completely factory assembled and conform to the specifications and schedules.

The closed circuit cooler shall have the capacity to cool ___ l/s water / glycol from ___°C to ___°C with a ___°C entering wet bulb temperature.

The total fan power should not exceed ___ kW.
The total pump power should not exceed ___ kW.

The total overall unit dimensions should not exceed the following:
Length: ___ mm Width: ___ mm Height: ___ mm

The maximum operating weight should not exceed ___ kg.

The unit will be delivered in two parts: the bottom basin - louver section and the heat transfer - fan section. The unit (top and bottom section) shall be joined together with elastic sealer and bolted together with corrosion resistant fasteners.

Approved manufacturer Evapco – model ATW _____

Thermal Performance – Performance Warranty

The tower shall be capable of performing the thermal duties as shown in the schedule and on drawings and its design thermal rating shall be certified by the manufacturer.

Applicable Standards

CTI ATC 128 Test Code for Measurement of Sound from Water Cooling Towers

Submittals

- a) The manufacturer shall submit a five year history of the proposed type of closed circuit cooler with a minimum of 10 installations for similar sized equipment.
- b) Shop drawings: submit shop drawings indicating dimensions, weight loadings and required clearances.
- c) Product data: submit manufacturers technical product data, original selection printouts and clearance requirements.
- d) Complete noise data sheet for the selected closed circuit cooler(s).
- e) Maintenance data for the closed circuit cooler(s) and accessories.
- f) The manufacturer shall provide factory test run certificates of the fans and fan motor.

Product Delivery – Storage and Handling

- a) The contractor shall make the provisions for proper storage at site before installation and handle the product per the instructions of the manufacturer.
- b) Once installed provide the necessary measures to keep units clean and protected from any dust and mechanical damage.

Quality Assurance

- a) The manufacturer shall have a quality assurance system in place which is certified by an accredited registrar and complying with the requirements of ISO 9001. This is to guarantee a consistent level of product and service quality.
- b) Manufacturers without ISO 9001 certification are not acceptable.

Warranty

- a) The products will be warranted for a period of minimum two years from the date of shipment.

PRODUCT

Construction – Corrosion Resistance

- a) The structure and all steel elements of the pan and casing shall be constructed of Z 725 hot dip galvanized steel for long life and durability. Alternatives with lower zinc layer thickness and external paint or coating are not accepted as equal.
- b) The strainer shall be made of stainless steel type 304.
- c) During fabrication all panel edges shall be coated with a 95 % pure zinc compound.
- d) Casing materials shall be of non flammable construction only.

OPTIONAL EXECUTION – BASIN IN AISI 304

Construction – Corrosion Resistance

- a) The structure and all steel elements of the Basin and Louver section up to the water level shall be made of stainless steel AISI 304.
- b) Alternatives with hot dip galvanized steel and epoxy coatings in lieu of the stainless steel AISI 304 are not considered to be equal and are not accepted.
- c) All other steel components of the casing shall be constructed of Z 725 hot dip galvanized steel for long life and durability. Alternatives with lower zinc layer thickness and external paint or coating or FRP materials are not accepted as equal.
- d) The strainer shall be made of stainless steel AISI 304.
- e) During fabrication all galvanized steel panel edges shall be coated with a 95 % pure zinc compound.
- f) Casing materials shall be of non flammable construction only.

OPTIONAL EXECUTION – COMPLETE UNIT IN

STAINLESS STEEL AISI 304 (except heat exchange coil(s))

Construction – Corrosion Resistance

- a) The structure and all steel elements shall be made of AISI 304.
- b) Alternatives with hot dip galvanized steel and epoxy coatings in lieu of the AISI 304 are not considered to be equal and are not accepted.
- c) The strainer shall be made of stainless steel AISI 304.
- d) Casing materials shall be of non flammable construction only.

Closed Circuit Cooler Basin

- a) Standard basin accessories include: overflow, drain, strainer and brass make up valve with plastic float ball.
- b) The strainer shall be made of AISI 304.
- c) The entire pan area shall incorporate a sloped and stepped basin design to prevent sediment built up, biological film and standing water.
- d) Upper and lower basin bottoms shall be sloped to provide drainage of the complete basin section.
- e) The basin can be inspected while the unit is in operation with the fan(s) and pump(s) running.

Air Inlet Louvers

- a) The air inlet louvers shall be constructed of UV inhibited polyvinyl chloride (PVC), mounted in easily removable frames for easy access to the basin.
- b) The louvers shall be at four sides to provide easy access to the basin interior.
- c) The louvers shall have a minimum of two changes in air direction to prevent splash out and block direct sunlight from entering the basin.
- d) The louvers will have a 19 mm opening to prevent debris from entering the basin.

Casing Section

Heat Transfer Coil

- a) The closed circuit cooler shall use internally enhanced heat exchange coils of an elliptical tube design to obtain lower air flow resistance and allow higher water loadings around the tubes.

SPECIFICATIONS

ATW

- b) The heat transfer coil(s) shall be made of all prime surface, encased in a steel framework and hot dip galvanized after fabrication as a complete assembly.
- c) The tubes shall be arranged in a self spacing, staggered pattern in the direction of air flow for maximum heat transfer efficiency and minimum pressure drop.
- d) The heat exchange coils shall be air pressure tested under water.
- e) The design and manufacturing process shall be approved and in accordance with the "Pressure Equipment Directive" – PED 97 / 23 EC.
- f) The manufacturer shall be responsible for the manufacturing and performance testing of the entire heat transfer coil. This is to assure single source responsibility.
- g) The casing shall totally encase the complete coil section to protect the complete coil from direct atmospheric contact.
- h) The pressure drop of the process fluid through the coil shall not exceed ____kPa.

Water Distribution

- a) The water distribution system shall be completely enclosed and protected from sunlight exposure, environmental elements and debris. Water distribution systems with direct exposure to the environment are not allowed.
- b) The spray header and branches shall be constructed of Schedule 40, Polyvinyl Chloride (PVC) pipe for corrosion resistance.
- c) The water shall be distributed over the coil by precision molded ZM spray nozzles with large minimum orifice openings and integral sludge ring to eliminate clogging.
- d) The nozzles shall be threaded into the water distribution piping to assure positive positioning and easy removal for maintenance. Snap in or strapped on nozzles are not accepted.

Water Circulation Pump

- a) The pump(s) shall be a close coupled, centrifugal type with mechanical seal, installed vertically at the factory to allow free drainage on shut down.
- b) A ____ kW totally enclosed motor(s) suitable for outdoor service shall be furnished.
- c) The motor shall be suitable for the following power supply: ____volts, ____hertz and ____ phase and ____ kW.

Drift Eliminators

- a) The drift eliminators shall be constructed of entirely inert polyvinyl (PVC) that has been specially treated to resist ultra violet light.
- b) Assembled in easily handled sections, the eliminator blades shall be spaced on 25 mm centers and shall incorporate three changes in air direction to assure efficient removal of entrained moisture from the discharge air stream.
- c) The maximum drift rate shall not exceed 0,001 % of the circulating water rate.

Access Door

- a) A large hinged access door shall provide access to the fan section for maintenance.

Mechanical Equipment

Axial Propeller Fan(s) (Standard)

- a) Fan shall be heavy duty wide chord axial propeller type, statically balanced and constructed of extruded aluminum alloy blades.
- b) Fans shall be installed in a closely fitted cowl with venturi air inlet for maximum fan efficiency.
- c) The fans shall utilize a soft connect blade to hub design, compatible with variable speed drives, to avoid transmission of vertical forces to the unit structure.
- d) Each fan blade shall be individually adjustable.
- e) The fan cowl shall be covered with a heavy gauge hot dip galvanized steel wire fan guard.
- f) The fan – drive system (fan – drive – motor) shall be

factory mounted, adjusted and undergo a trial run in the factory before shipment.

Axial Propeller Fan(s) - Low Sound Fan (Alternative)

- a) Fan shall be heavy duty wide chord axial propeller type, statically balanced and constructed of extruded aluminum alloy blades.
- b) Fans shall be installed in a closely fitted cowl with venturi air inlet for maximum fan efficiency.
- c) The fans shall utilize a soft connect blade to hub design, compatible with variable speed drives, to avoid transmission of vertical forces to the unit structure.
- d) Each fan blade shall be individually adjustable.
- e) The fan cowl shall be covered with a heavy gauge hot dip galvanized steel wire fan guard.
- f) The fan – drive system (fan – drive – motor) shall be factory mounted, adjusted and undergo a trial run in the factory before shipment.

Axial Propeller Fan(s) - Super Low Sound Fan (Alternative)

- a) Fan shall be extremely wide chord axial, one piece heavy duty propeller type, statically balanced and made of FRP.
- b) Fans will be installed in a closely fitted cowl with venturi air inlet for maximum fan efficiency.
- c) The fan cowl shall be covered with a heavy gauge hot dip galvanized steel wire fan guard.
- d) The fan – drive system (fan – drive – motor) shall be factory mounted, adjusted and undergo a trial run in the factory before shipment.
- e) The fans are high efficiency and operate with no loss of thermal performance

Bearings and Drive

- a) The fan shaft (s) shall be supported by heavy duty, self aligning ball type bearings with cast iron housings.
- b) The bearings shall be rated for an L-10 life of 75000 hours.
- c) The fan drive sheaves shall be aluminum alloy.
- d) The belt shall be a multigroove belt system, constructed of neoprene with polyester cords and designed for 150% of the motor nameplate horsepower.
- e) The grease fittings shall be extended to a location just inside the access door.

Motor (0.9, 1.2 and 2.4 meter wide Models)

- a) The fan motor shall be Totally Enclosed Fan Cooled (TEFC), squirrel cage, ball bearing type motor.
- b) The motor shall be specially designed for cooling tower use with moisture protection on the winding, shaft and bearings.
- c) The motor shall be minimum IP 55 degree of protection, Class F insulation, Service Factor 1 and selected for the appropriate cooling tower duty and the correct ambient temperature but minimum 40°C.
- d) Motors bearings shall be double sealed non-relubricable or external grease nipples shall be provided.
- e) The motor shall be mounted on an adjustable heavy duty steel motor base.
- f) A hinged protective cover shall shield the motor and sheave from the weather.
- g) The motor power supply shall be ____ volts, ____ hertz and ____ phase.

Motor (3 and 3.6 meter wide Models)

- a) The fan motor shall be Totally Enclosed Air Over (TEAO), squirrel cage, ball bearing type motor.
- b) The motor shall be specially designed for cooling tower use with moisture protection on the windings, shaft and bearings.
- c) The motor shall be minimum IP 55 degree of protection, Class F insulation, Service Factor 1 and selected for the appropriate cooling tower duty and the correct ambient temperature but minimum 40°C.
- d) Motor bearings shall be double sealed non-relubricable or external grease nipples shall be provided.
- e) The motor shall be mounted on an adjustable heavy duty steel motor base.

ATW

SPECIFICATIONS

- f) The motor base shall be able to swing to the outside of the unit for repair or removal.
- g) The motor power supply shall be ___ volts, ___ hertz and ___ phase.

Sound Levels

Sound Level

The maximum sound pressure levels (dB) measured 1.5 m 45° from the top of the closed circuit cooler operating at full fan speed shall not exceed the sound levels detailed below.

Location	63 Hz	125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz	8000 Hz	dB(A)
Fan discharge									
Air inlet /end									

ACCESSORIES (Optional)

Electric Heaters

- a) The closed circuit cooler cold water basin shall be provided with an electric heater package to prevent freezing of the water in the cold water basin, when the pump is shut down.
- b) The electric heater package includes: electric heater element(s), thermostat and low water level cutoff.
- c) The heaters shall be selected to maintain 4 °C basin water temperature at ___ °C ambient
- d) The heater(s) shall be ___ V / ___ phase / ___ Hz electric power supply.

Three Probe Electric Water Level Control Package

- a) The closed circuit cooler manufacturer shall provide an electric water level control package instead of the mechanical float valve arrangement.
- b) The package consist of the following elements :
 - Multiple heavy duty stainless steel 316 static sensors mounted in a stilling chamber outside the unit. Electrodes or sensors mounted inside the unit are not accepted as their operation will be disturbed by the moving water in the basin.
 - An ABS, IP 56 case contains all the contactors for the different level probes and will provide an output signal of a relay for automatic filling and one relay for alarm level.
 - The power supply to the control package is 24 Vac / 230 Vac - ___ Hz .
 - A weather protected solenoid valve (PN16) for the water make up ready for piping to a water supply with pressure between 140 kPa and 340 kPa.

Vibration Switch

- a) A vibration limit switch shall be installed on the mechanical equipment support and wired into the control panel. The purpose of this switch is to interrupt power to the motor in the event of excessive vibration.
- b) The switch shall be adjustable for sensitivity and shall require manual reset.

Vertical Access Ladders

- a) A vertical ladder with safety cage which provide easy access to the water distribution system and drive components shall be provided with the closed circuit cooler(s).
- b) The ladder will be completed with a safety cage for safety purposes.
- c) Ladder safety cage shall meet OSHA - CE - BS requirements.

Service Platform

- a) The closed circuit cooler shall be supplied with an external service platform.
- b) The external service platform will be self supporting and include access ladders to the platform.
- c) The external service platform will be installed in front of the fan access doors.

- d) The platform shall meet OSHA - CE - BS requirements.

Motor Davit

- a) The closed circuit cooler shall be supplied with a motor davit to facilitate the removal of fan motor(s) and fan(s).
- b) The davit and braket are constructed of aluminum and are mounted on the side of the unit.
- c) The fan motor davit ships loose with the unit and is installed in the field.

Water Silencer

- a) The water silencers are located in the falling water area of the cold water basin.
- b) The water silencers will reduce the overall sound levels 4 dB (A) to 7 dB (A) measured at 1.5 m from the side or end of the unit, when the fans are running, and 9 dB (A) to 12 dB (A) when fans are off.
- c) The water silencers are constructed of lightweight PVC sections and can be easily removed for access to the basin area.
- d) The water silencers will have no impact on the unit's thermal performance.

ATW

Notes:



World Headquarters/
Research and
Development Center

EVAPCO Manufacturing
Locations

EVAPCO, Inc. - World Headquarters & Research / Development Center

P.O. Box 1300 • Westminster, MD 21158 USA
Ph: +1 410-756-2600 • Fx: +1 410-756-6450 • marketing@evapco.com

North America

EVAPCO, Inc.
World Headquarters
P.O. Box 1300
Westminster, MD 21158 USA
Ph: 410-756-2600 - Fx: 410-756-6450
marketing@evapco.com

EVAPCO East
5151 Allendale Lane
Taneytown, MD 21787 USA
Ph: 410-756-2600 - Fx: 410-756-6450
marketing@evapco.com

EVAPCO Midwest
1723 York Road
Greenup, IL 62428 USA
Ph: 217-923-3431 - Fx: 217-923-3300
evapcomw@evapcomw.com

EVAPCO West
1900 West Almond Avenue
Madera, CA 93637 USA
Ph: 559-673-2207 - Fx: 559-673-2378
contact@evapcowest.com

EVAPCO Iowa
925 Quality Drive
Lake View, IA 51450 USA
Ph: 712-657-3223 - Fx: 712-657-3226

**EVAPCO Iowa
Sales & Engineering**
215 1st Street, NE
P.O. Box 88
Medford, MN 55049 USA
Ph: 507-446-8005 - Fx: 507-446-8239
evapcomn@evapcomn.com

EVAPCO Newton
701 East Jourdan Street
Newton, IL 62448 USA
Ph: 618-783-3433 - Fx: 618-783-3499
evapcomw@evapcomw.com

EVAPCOLD
521 Evapco Drive
Greenup, IL 62428 USA
Ph: 217-923-3431
evapcomw@evapcomw.com

EVAPCO-BLCT Dry Cooling, Inc.
981 US Highway 22 West
Bridgewater, NJ 08807 USA
Ph: 1-908-379-2665
info@evapco-blct.com

**Refrigeration Valves &
Systems Corporation**
A wholly owned subsidiary of EVAPCO, Inc.
1520 Crosswind Dr.
Bryan, TX 77808 USA
Ph: 979-778-0095 - Fx: 979-778-0030
rvs@rvscorp.com

Evapco Northwest
5775 S.W. Jean Road, Suite 104
Lake Oswego, OR 97035 USA
Ph: 503-639-2137 - Fx: 503-639-1800

EvapTech, Inc.
A wholly owned subsidiary of EVAPCO, Inc.
8331 Nieman Road
Lenexa, KS 66214 USA
Ph: 913-322-5165 - Fx: 913-322-5166
marketing@evaptechnic.com

Tower Components, Inc.
A wholly owned subsidiary of EVAPCO, Inc.
5960 US HWY 64E
Ramseur, NC 27316
Ph: 336-824-2102 - Fx: 336-824-2190
mail@towercomponentsinc.com

South America

**Evapco Brasil
Equipamentos Industriais Ltda**
Rua Alexandre Dumas 1601
04717-004 Sao Paulo - SP - Brazil
Ph: (55) 19-5681-2000

Europe

**EVAPCO Europe BVBA
European Headquarters**
Heersterveldweg 19, Industrieterrein Oost
3700 Tongeren, Belgium
Ph: (32) 12-395029 - Fx: (32) 12-238527
evapco.europe@evapco.be

EVAPCO Europe, S.r.l.
Via Ciro Menotti 10
I-20017 Passirana di Rho, Milan, Italy
Ph: (39) 02-939-9041 - Fx: (39) 02-935-00840
evapcoeuropa@evapco.it

EVAPCO Europe, S.r.l.
Via Dosso 2
23020 Piateda Sondrio, Italy

EVAPCO Europe, GmbH
Insterburger Straße, 18
D-40670 Meerbusch, Germany
Ph: (49) 2159-69560 - Fx: (49) 2159-695611
info@evapco.de

Flex Coil a/s
A wholly owned subsidiary of EVAPCO, Inc.
Knøsgårdvej 115
9440 Aabybro, Denmark
Ph: (45) 9824-4999 - Fx: (45) 9824-4990
flexcoil@flexcoil.dk

EVAPCO S.A. (Pty) Ltd.
A licensed manufacturer of Evapco, Inc.
18 Quality Road
Isando 1600, Republic of South Africa
Ph: (27) 11 392-6630 - Fx: (27) 11-392-6615
evapco@evapco.co.za

Evap Egypt Engineering Industries Co.
A licensed manufacturer of Evapco, Inc.
5 Al Nasr Road St.
Nasr City, Cairo, Egypt
Ph: (20) 2-24022866 / (20) 2-24044997/8
Fx: (20) 2-404-4667/ Mob: (20) 12-3917979
primacool@link.net / shady@primacool.net

Asia/Pacific

**EVAPCO China
Asia/Pacific Headquarters**
1159 Luoning Rd. Baoshan Industrial Zone
Shanghai, P. R. China, Postal Code: 200949
Ph: (86) 21-6687-7786 - Fx: (86) 21-6687-7008
marketing@evapcochina.com

**Evapco (Shanghai) Refrigeration
Equipment Co., Ltd.**
1159 Louning Rd., Baoshan Industrial Zone
Shanghai, P.R. China, Postal Code: 200949
Ph: (86) 21-6687-7786 - Fx: (86) 21-6687-7008
marketing@evapcochina.com

**Beijing EVAPCO Refrigeration
Equipment Co., Ltd.**
Yan Qi Industrial Development District
Huai Rou County
Beijing, P.R. China, Postal Code: 101407
Ph: (86) 10 6166-7238 - Fx: (86) 10 6166-7395
evapcoobj@evapcochina.com

EVAPCO Australia Pty Ltd.
34-42 Melbourne Road - P.O. Box 436
Riverstone, N.S.W. Australia 2765
Ph: (61) 29 627-3322 - Fx: (61) 29 627-1715
sales@evapco.com.au

EvapTech Composites Sdn. Bhd
No. 70 (Lot 1289) Jalan Industri 2/3
Rawang Integrated Industrial Park
Rawang, Selangor, 48000 Malaysia
Ph: 60 3 6092-2209 - Fx: 60 3 6092-2210

EvapTech Asia Pacific Sdn. Bhd
A wholly owned subsidiary of EvapTech, Inc.
IOI Business Park, 2/F Unit 20
Persiaran Puchong Jaya Selatan
Bandar Puchong Jaya,
47170 Puchong, Selangor, Malaysia
Ph: +(60-3) 8070 7255 - Fx: +(60-3) 8070 5731
marketing-ap@evaptech.com



EVAPCO... Specialists in Heat Transfer Products and Services.
Visit EVAPCO's Websites at: www.evapco.eu / www.mrgoodtower.eu

